

-----Original Message-----

From: Norman Pedley
Sent: 09 November 2007 11:37
To: Sarah Westwood
Subject: Planning Application 3/2007/0941

Former Gee Co site, Up Brooks, Clitheroe

Thank you for consulting me regarding this proposal.

I would make the following comments and recommendations:

The details, including acoustic specifications, of all fixed plant, machinery and equipment associated with air moving equipment, compressors, generators or plant or equipment of a like kind installed within the site, shall be submitted to and approved by the Local Planning Authority before installation.

Due to the proximity of residential properties I would recommend that no such plant or equipment be installed on the the South, East elevation of Unit 2, or Unit 1A and B.

The above measures being to protect the amenity of adjacent residential properties