

Contact: Please contact the Local Planning Authority

Date: 31 October 2022

Dear Local Planning Authority,

Thank you for inviting the Lead Local Flood Authority to comment on the below application.

PLANNING APPLICATION CONSULTATION RESPONSE

Application Number:	3/2022/1003
Proposal:	Discharge of Condition 21 (Compensatory Storage) of application 3/2021/0205.
Location:	Land at Neddy Lane, Billington, BB7 9LL

The Lead Local Flood Authority is a statutory consultee for major developments with surface water drainage, under the Town and Country Planning (Development Management Procedure) (England) Order 2015. It is in this capacity this response is compiled.

Comments provided in this representation, including conditions, are advisory and it is the decision of the Local Planning Authority whether any such recommendations are acted upon. The comments given have been composed based on the extent of the knowledge of the Lead Local Flood Authority and information provided with the application at the time of this response.

Lead Local Flood Authority Position

The Lead Local Flood Authority has **no comments** to make on the above application, as the proposed development seeks to discharge a condition that the Lead Local Flood Authority did not previously recommended.

If not already done so the Lead Local Flood Authority advises the Local Planning Authority to consult with the Environment Agency due to this condition relating to flood compensatory storage

If the applicant wishes to discuss any aspects of this response with the Lead Local Flood Authority, they can do so through our planning advice service. This service is offered to

prevent any issues that could potentially affect your application and provide relevant up to date advice regarding surface water flood risk and sustainable drainage.

More information on our planning advice service is available at: <https://www.lancashire.gov.uk/business/business-services/pre-planning-application-advice-service/lead-local-flood-authority-planning-advice-service-for-surface-water-and-sustainable-drainage/>

What this response DOES NOT cover

This response does not cover highway drainage, matters pertaining to highway adoption (s38 Highways Act 1980) and/or off-site highway works (s278 Highways Act 1980). Should the applicant intend to install any sustainable drainage systems under or within close proximity to a public road network (existing or proposed), then they would need to separately discuss the use and suitability of those systems with the relevant highway authority.

The applicant is encouraged to discuss the suitability of any overland flow routes and/or flood water exceedance with the relevant highway authority should they have the potential to impact the public highway network and/or public highway drainage infrastructure (either existing or proposed).

Material Changes or Additional Information to this Planning Application

If there are any material changes to the submitted information or additional information provided after this Lead Local Flood Authority response to the Local Planning Authority which impact surface water, the Local Planning Authority is advised to re-consult the Lead Local Flood Authority. Please be aware this will be classed as a re-consultation with a full 21-day response time. Re-consultations should be sent to our identified mailbox.

Please note that should the Local Planning Authority make a decision on this application contrary to our advice, then we will be unable to support this application in an appeal or at any future discharge of conditions stage relating to conditions that the Lead Local Flood Authority have not recommended.

Please send a copy of the decision notice to our identified mailbox.

Yours faithfully,

Harry McGaghey

Lead Local Flood Authority

