

Direct Line 01925 678309
Jillian.Walker@uuplc.co.uk

Colin Sharpe
Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Your ref	3/2011/0460
Our ref	DC/11/2374
Date	07-JUL-11

Dear Mr Sharpe,

Location: Land at Whalley New Road, Billington
Proposal: Residential development (34No dwellings)

Thank you for your planning consultation of 20 June 2011.

I have no objection to the application, the drainage design submitted is acceptable in principle to United Utilities.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers.

Our water mains will need extending to serve any development on this site. The applicant, who may be required to pay a capital contribution, will need to sign an Agreement under Sections 41, 42 & 43 of the Water Industry Act 1991.

United Utilities encourages the use of water efficient designs and development wherever this is possible. The most up to date advice for water efficiency and water efficiency products can be found at Water wise who have recently published a best practice guide on water efficiency for new developments. We would encourage utilisation of the following water efficiency activities:

Installing the latest water efficient products, such as a 4.5l flush toilet instead of the 6l type. Minimise run lengths of hot and cold water pipes from storage to tap/shower areas. This minimises the amount of waste during the time the water goes from cold to hot. Utilising drought resistant varieties of trees, plants and grasses when landscaping. Install water efficient appliances such as dishwashers, washing machines.

United Utilities offers a fully supported mapping service at a modest cost for our electricity, water mains and sewerage assets. This is a service, which is constantly updated by our Map Services Team (Tel No: 0870 7510101) and I recommend that the

applicant give early consideration in project design as it is better value than traditional methods of data gathering. It is, however, the applicant's responsibility to demonstrate the exact relationship on site between any assets that may cross the site and any proposed development.

Please note that a copy of these comments has been forwarded to the agent.

Yours Sincerely

Jillian Walker
United Utilities
Asset Protection