



5065 GT
United Utilities Water PLC
Developer Services & Asset Protection
Thirlmere House
Lingley Mere Business Park
Lingley Green Avenue
Great Sankey
Warrington WA5 3LP

Telephone 01925 678307
Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2011/0784
Our ref: DC/11/4809
Date: 09-DEC-11
09 MAR 12

Dear Sir/Madam,

Location: Old Whalley Nurseries Lamb Row, Clitheroe Road Whalley
Proposal: Six Dwellings

Thank you for your planning consultation of 16/11/2011

After completing a flow and load assessment of the above site United Utilities will have no Objections to this development.

A separate metered Supply to each unit will be required at the applicant's expense and all internal pipe work must comply with current water supply(water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our service Enquires on 0845 7462200 regarding connection to the water mains/public sewers

Yours Faithfully

Daniel McDermott
Developer Services & Asset Protection
United Utilities

