



Direct Line 01925 678308
Planning.Liaison@uuplc.co.uk

Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Your ref 3/2011/0971
Our ref DC/11/5092
Date 03-JAN-12

Dear Sir/Madam,

Location : Cobden Mill Watt Street Sabden Lancashire BB7 9DZ
Proposal : Reserved matters application for approval of Appearance and Landscaping, following outline approval for regeneration of the site to provide 44 dwellings (6 of which would be affordable) with access from Watt St. and associated parking. Retention and refur...

Thank you for your planning consultation of 09/12/2011.

We do not have any comment to make on these reserved matters as the information submitted does not appear to impact on the surface water or foul water management on the site. Therefore I would ask that conditions 8, 10 & 11 remain in place until a suitable drainage scheme has been submitted

We can readily supply water for domestic purposes, but for larger quantities we will need further information.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers.

United Utilities encourages the use of water efficient designs and development wherever this is possible. The most up to date advice for water efficiency and water efficiency products can be found at Water wise who have recently published a best practice guide on water efficiency for new developments. We would encourage utilisation of the following water efficiency activities:

Installing the latest water efficient products, such as a 4.5l flush toilet instead of the 6l type. Minimise run lengths of hot and cold water pipes from storage to tap/shower areas. This minimises the amount of waste during the time the water goes from cold to hot. Utilising drought resistant varieties of trees, plants and grasses when landscaping. Install water efficient appliances such as dishwashers, washing machines.

United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101) and I recommend that the applicant give early consideration in project design as it is better value than traditional methods of data gathering. It is, however, the applicant's responsibility to demonstrate the exact relationship on site between any assets that may cross the site and any proposed development

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours Faithfully,

Lorna Church
Asset Protection
United Utilities