

4957  
GT

Ribble Valley Borough Council  
Council Officers, Church Walk  
Clitheroe  
BB7 2RA

Direct Line 01925 678308  
Planning.Liaison@uuplc.co.uk

**Your ref** 3/2012/0086  
**Our ref** DC/12/793  
**Date** 23-FEB-12

Dear Sir/Madam,

**Location : Old Motor Repair Workshop Neville Street Longridge Lancashire**  
**Proposal : Outline application to demolish the existing building and to erect a two-storey dwelling house**

With reference to the above planning application, I will have **no objection** to the proposal.

If possible this site should be drained on a separate system, with only foul drainage connected into the foul sewer. Surface water should discharge to the watercourse (as stated in the planning application) or surface water sewer and may require the consent of the Environment Agency. If surface water is allowed to be discharged to the public surface water sewerage system we may require the flow to be attenuated to a maximum discharge rate determined by United Utilities.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development.

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours Faithfully,

Lorna Church  
Developer Services and Asset Protection  
United Utilities

