

Jane Tucker

From: Hewitt, Amy [Amy.Hewitt@uuplc.co.uk]
Sent: 15 March 2012 11:42
To: planning
Subject: Extension applications showing on the weekly list ending 9th March
Attachments: Ribble Valley.doc

Dear Sir/Madam,

Please find attached our response for extension applications showing on the weekly list ending 9th March

Please be advised for application 3/2012/0176, our records indicate that there is a water main along the rear of the property and we cannot permit building over or near to it. Therefore the applicant should contact our Regional mains Diversions Team on 01925 677994 to discuss this matter.

Kind regards
Amy Hewitt
United Utilities


*Asset Protection Analyst
Thirlmere House
Lingley Mere
Warrington
WA5 3LP*

Email: Amy.Hewitt@uuplc.co.uk
External: 01925 678785 Internal: 78785

The information contained in this e-mail is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this Message in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy or alter this message for any unauthorised purpose. Neither United Utilities Group PLC nor any of its subsidiaries will be liable for any direct, special, indirect or consequential damages as a result of any virus being passed on, or arising from the alteration of the contents of this message by a third party.

United Utilities Group PLC, Haweswater House, Lingley Mere Business Park, Lingley Green Avenue, Great Sankey, Warrington, WA5 3LP
Registered in England and Wales. Registered No 6559020

www.unitedutilities.com
www.unitedutilities.com/subsidiaries



United Utilities
Pipe Asset Register

© The plan is based upon the Ordnance Survey Map with the sanction of the Controller of H.M Stationery Office. Crown and United Utilities copyrights are reserved. Unauthorised reproduction will infringe these copyrights.