

Louise Blatchford

From: Terry Longden
Sent: 02 May 2012 09:38
To: Louise Blatchford
Cc: Simon Hartley

CS

Subject: RE: Planning applications and contaminated land 3/2012/0219

Contaminated Land Prior to the commencement of development, the following information shall be submitted to the Local Planning Authority (LPA) for approval in writing:

- (a) A Desk Study which assesses the risk of the potential for on-site contamination and ground gases and migration of both on and off-site contamination and ground gases.
- (b) If the Desk Study identifies potential contamination and ground gases, a detailed Site Investigation shall be carried out to address the nature, degree and distribution of contamination and ground gases and shall include an identification and assessment of the risk to receptors as defined under the Environmental Protection Act 1990, Part IIA, focusing primarily on risks to human health and controlled waters. The investigation shall also address the implications of the health and safety of site workers, of nearby occupied building structures, on services and landscaping schemes and on wider environmental receptors including ecological systems and property.

The sampling and analytical strategy shall be submitted to and be approved in writing by the LPA prior to the start of the site investigation survey.

- (c) A Remediation Statement, detailing the recommendations and remedial measures to be implemented within the site.

Any works identified in these reports shall be undertaken when required with all remedial works implemented by the developer prior to occupation of the first and subsequent dwellings. On completion of the development/remedial works, the developer shall submit written confirmation, in the form of a Verification Report, to the LPA, that all works were completed in accordance with the agreed Remediation Statement.

REASON: To ensure that the site investigation and remediation strategy will not cause pollution of ground and surface waters both on and off

Terry Longden
Head of Engineering Services
 Tel.01200 414523
 Mob 07932 604 981
terry.longden@ribblevalley.gov.uk

From: Louise Blatchford
Sent: 19 March 2012 09:15
To: Terry Longden
Subject: Planning applications and contaminated land

Terry

Application 3/2012/0219 for demolition of existing building and erection of replacement 1,265sq m (13,618sq ft.) water extraction, bottling and storage facility including ancillary offices, welfare facilities and the construction of a new access, vehicle parking and all associated engineering works at Altham Pumping Station, Burnley Road, Simonstone - grid ref = 377407 433189. (A tiny part of the application site is located within contaminated land overlays on GGP).

Louise

02/05/2012