

Ribble Valley Borough Council
Development Control
Council Offices Church Walk
Clitheroe
Lancashire
BB7 2RA

Our ref: NO/2012/103741/01-L01
Your ref: 120399 3/2012/0399
Date: 07 June 2012

Dear Sir/Madam

**CREATION OF PRIVATE SWIMMING POOL FOR TEACHING PRURPOSES.
POOL WILL ONLY BE OPEN FOR PRE BOOKED LESSONS HIGHER
COLLEGE FARM LOWER ROAD, HOTHERSALL, PRESTON, PR3 2YY.**

Thank you for referring the above applications for consultation which we received on the 10 May 2012.

We have no objections to the proposed development but request that the following information is passed onto the applicant:

Informative

- 1) Sewage treatment is to be via a package treatment plant, the discharge from this may require an Environmental Permit (discharge consent) for discharge to either surface water or groundwater.
- 2) There must be no discharges of chlorinated water from the pool directly to any surface water drains or watercourses. Chlorinated water is highly polluting and would require proper treatment prior to discharge.

Yours faithfully

Amy Heys
Planning Liaison Technical Specialist

Direct dial 01768 215716
Direct fax 01768 865606
Direct e-mail nwnorthplanning@environment-agency.gov.uk

Environment Agency
Ghyll Mount (Gillan Way) Penrith 40 Business Park, Penrith, Cumbria, CA11 9BP.
Customer services line: 03708 506 506
www.environment-agency.gov.uk
Cont/d...

15 JUN 2012

RECEIVED
15 JUN 2012