



5662
GT
United Utilities Water PLC
Developer Services & Asset Protection
Thirlmere House
Lingley Mere Business Park
Lingley Green Avenue
Great Sankey
Warrington WA5 3LP

Telephone 01925 678307
Planning.liaison@uuplc.co.uk

South Ribble Borough Council
Civic Centre West Paddock
Leyland
PR5 1DH

Your ref: 3/2012/0399
Our ref: DC/12/1997
Date: 16-MAY-12

Dear Sir/Madam

Location: Higher College Farm Blackburn Road Longridge Lancashire
Proposal: Creation of a private swimming pool for teaching purposes.

With reference to the above planning application,

I have no objection to the proposed development.

Please note United Utilities have no waste water assets within the vicinity of this development.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers.

United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development.

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours Faithfully,

Daniel McDermott
Developer Services & Asset Protection
United Utilities