

Ribble Valley Borough Council
Council Offices
Church Walk
Clitheroe
Lancashire
BB7 2RA

Our ref: NO/2012/103940/01-L01
Your ref: 3/2012/0502
Date: 10 July 2012

Dear Sir

**DISCHARGE CONDITION 3 OF PREVIOUSLY APPROVED APPLICATION
3/2012/0090
LAND OFF PRIVATE ACCESS TRACK LEADING TO FOOTHOLME PUMPING
STATION, ACCESSED OFF NEWTON ROAD, DUNSOP BRIDGE**

Thank you for consulting with us on the above application to discharge condition 3 of planning approval 3/2012/0090 which we received on the 20 June 2012.

We no objections should you wish to discharge condition 3, although we would like to highlight the following point.

Point 3 of the incident response plan states:

‘Policies will be in place to minimise risk of pollution occurring (bunded tanks, **storage away from watercourse**, on site control....)’

Storage should also be located as far away as possible from the abstraction borehole associated with the groundwater source protection zone 1.

Yours faithfully

**Miss Jilly Dixon
Planning Liaison Officer**

Direct dial 01768 215789
E-mail nwnorthplanning@environment-agency.gov.uk