

Helen Booth

**From:** Jameson, Patricia [Patricia.Jameson@uuplc.co.uk]  
**Sent:** 07 September 2012 14:59  
**To:** planning  
**Subject:** FW: 3/2012/0735

**From:** Jameson, Patricia  
**Sent:** 07 September 2012 12:47  
**To:** 'planning@ribble.gov.uk'  
**Subject:** 3/2012/0735

Ribble Valley Borough Council  
Council Officers, Church Walk  
Clitheroe  
BB7 2RA

**Your ref:** 3/2012/0735  
**Our ref:** DC/12/3698  
**Date:** 07-SEP-12

**Location :** Jacksons Barn Bolton-by-Bowland Road Sawley Lancashire  
**Proposal :** Proposed conversion of a redundant agricultural building forming a mixed use. Ground floor office wi

With reference to the above planning application

I have no objection to the proposed development

If possible this site should be drained on a separate system, with only foul drainage connected into the foul sewer. Surface water should discharge to the soakaway/watercourse/surface water sewer and may require the consent of the Local Authority. If surface water is allowed to be discharged to the public surface water sewerage system we may require the flow to be attenuated to a maximum discharge rate determined by United Utilities.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers. United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development

Please note, due to the public sewer transfer not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction please contact a Building Control Body to discuss the matter further

Yours faithfully

Patricia Jameson  
United Utilities  
Developer Services and Planning

=====

The information contained in this e-mail is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this Message in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy or alter this message for any unauthorised purpose. Neither United Utilities Group PLC nor any of its subsidiaries will be liable for any direct, special, indirect or consequential damages as a result of any virus being passed on, or arising from the alteration of the contents of this message by a third party.

United Utilities Group PLC, Haweswater House, Lingley Mere  
Business Park, Lingley Green Avenue, Great Sankey,  
Warrington, WA5 3LP  
Registered in England and Wales. Registered No 6559020

www.unitedutilities.com  
www.unitedutilities.com/subsidiaries

=====

07/09/2012