



United Utilities Water PLC Developer Services & Planning

Thirlmere House Lingley Mere Business Park Lingley Green Avenue Great Sankey Warrington WA5 3LP

Telephone 01925 678307 Planning liaison@uuplc.co.uk

Ribble Valley Borough Council Council Officers, Church Walk

Clitheroe BB7 2RA

Your ref: Our ref: 1 2 NOV 2012 Date:

3/2012/0786 DC/12/4305 12-NOV-12

Dear Sir/Madam

Location: Clitheroe Hospital Chatburn Road Clitheroe Lancashire

Proposal: Proposed erection of a two-storey Community Hospital including associated

works

With reference to the above planning application,

This site must be drained on a separate system, with only foul drainage connected into the foul sewer. Surface water should discharge to the soakaway/SUDS or directly to watercourse which may require the consent of the Local Authority. Surface water should not be allowed to drain to the public sewer.

A public sewer crosses this site and we will not permit building over it. We will require an access strip width of 6 metres, 3 metres either side of the centre line of the sewer which is in accordance with the minimum distances specified in the current issue of "Sewers for Adoption", for maintenance or replacement.

A modification of the site layout, or a diversion of the affected public sewer at the applicant's expense, may be necessary. To establish if a sewer diversion is feasible, the applicant must discuss this at an early stage with Graham Perry, the Developer Enquiries Analyst by email, planning liaison@uuplc.co.uk as a lengthy lead in period may be required if a sewer diversion proves to be acceptable.

I will have no objection to the proposal provided that the following conditions are attached to any approval

Notwithstanding any indication on the approved plans, no development approved by this permission shall commence until a scheme for the disposal of foul and surface waters has been submitted to and approved in writing by the Local Planning Authority. For the avoidance of doubt, surface water must drain separate from the foul and no surface water will be permitted to discharge directly or indirectly into existing foul, combined or surface water sewerage systems. The development shall be completed, maintained and managed in accordance with the approved details.

Reason: To secure proper drainage and to reduce the risk of flooding.

 Notwithstanding any indication on the approved plans, no development approved by this permission shall be commenced until a scheme for the provision and implementation of a surface water regulation system, restricting surface water discharge to 5 l/s or Greenfield runoff rate equivalent to Qbar whichever is the greater, has been approved by the Local Planning Authority. The development shall be completed, maintained and managed in accordance with the approved details.

Reason: To secure proper drainage and to reduce the risk of flooding.

We can readily supply water for domestic purposes, but for larger quantities we will need further information.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers.

United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours Faithfully,

Daniel McDermott
Developer Services & Asset Protection
United Utilities