

Name

1650 CS

**Jane Tucker**

**From:** Jameson, Patricia [Patricia.Jameson@uuplc.co.uk]  
**Sent:** 21 September 2012 12:49  
**To:** planning  
**Subject:** 3/2012/0819

Ribble Valley Borough Council  
Council Officers, Church Walk  
Clitheroe  
BB7 2RA

**Your ref:** 3/2012/0819  
**Our ref:** DC/12/3912  
**Date:** 21-SEP-12

**Location : The Moorcock Inn Slaidburn Road Waddington Lancashire**  
**Proposal : demolition of The Moorcock Inn and the erection of three detached dwellings, three detached garages**

With reference to the above planning application, I have no objection to the proposed development.

If possible this site should be drained on a separate system, with only foul drainage connected into the foul sewer.

Surface water should discharge to the soakaway/watercourse/surface water sewer and may require the consent of the Local Authority. If surface water is allowed to be discharged to the public surface water sewerage system we may require the flow to be attenuated to a maximum discharge rate determined by United Utilities.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers. United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours faithfully

Patricia Jameson  
United Utilities  
Developer Services and Planning

21 SEP 2012  
FOR THE  
ATTENTION OF

The information contained in this e-mail is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this Message in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy, or otherwise disseminate the information contained in this message.