



GT
United Utilities Water PLC
Developer Services & Planning
Thirlmere House
Lingley Mere Business Park
Lingley Green Avenue
Great Sankey
Warrington WA5 3LP


Telephone 01925 678307
Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2012/0862
Our ref: DC/12/4308
Date: 12-NOV-12

Dear Sir/Madam

Location: Fell View Barnacre Road Longridge
Proposal: Outline Application for 9 Dwellings



With reference to the above planning application,

I will have no objection to the proposal provided that the following conditions are attached to any approval

This site must be drained on a separate system, with only foul drainage connected into the foul sewer. Surface water should discharge to the soakaway/SUDS directly to watercourse or drain to surface water sewer which may require the consent of the Local Authority.

If surface water is allowed to be discharged to the public surface water sewerage system we will require the flow to be attenuated to a maximum discharge rate of 5 l/s or greenfield runoff whichever is the greater.

- Prior to the commencement of any phase of the development, details for surface water drainage and means of disposal for that phase, based on sustainable drainage principles and evidence of an assessment of site conditions (inclusive of how the scheme shall be maintained and managed after completion and any necessary infrastructure) shall be submitted to and approved in writing by the local planning authority. For the avoidance of doubt, no surface water shall discharge into the public foul or combined sewerage system, directly or indirectly, in accordance with the submitted application form. Any residual surface water draining to the public surface water sewer must be restricted to a maximum pass forward flow of 5 l/s. The development shall be completed, maintained and managed in accordance with the approved details.

Reason: To secure proper drainage and to reduce the risk of flooding.

- Notwithstanding any indication on the approved plans, no development approved by this permission shall commence until a scheme for the disposal of foul and surface waters has been submitted to and approved in writing by the Local Planning Authority. The development shall be completed, maintained and managed in accordance with the approved details.

Reason: To secure proper drainage and to reduce the risk of flooding.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers.

United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours Faithfully,

Daniel McDermott
Developer Services & Asset Protection
United Utilities