




**United Utilities Water PLC
Developer Services & Planning**
Thirlmere House
Lingley Mere Business Park
Lingley Green Avenue
Great Sankey
Warrington WA5 3LP

Telephone 01925 678307
Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2013/0214
Our ref: DC/13/1241
Date: 15-APR-13

Dear Sir/Madam

Location: Over Hacking Farm, Stonyhurst, Clitheroe
Proposal: Slurry Lagoon

With reference to the above planning application,

The footprint of the proposed slurry lagoon is directly over our large diameter trunk main. This 30" pumped pipe supplies treated water to many thousands of customers in the Ribble Valley and Blackburn areas. The main is protected by formal easement preventing any significant changes in level of cover such as proposed in this application. The presence of slurry on and adjacent to the main would create a significant risk of contamination to the water supply and we therefore object to the proposed development.

Diversion of the main is prohibitively expensive and disruptive to water supplies

Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Yours Faithfully,

Daniel McDermott
Developer Services & Asset Protection

United Utilities

