


Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2013/0307
Our ref: DC/13/1875
Date: 30-MAY-13



Dear Sir/Madam,

Location : Land off Preston Rd Longridge

Proposal : Erection of 58 dwellings with layout scale appearance and landscaping

With reference to the above planning application.

I will have no objection to the proposal provided that the following condition is met: -

Drainage

- This site must be drained on a separate system, with only foul drainage connected into the foul sewer. Surface water should discharge directly to soakaway and or watercourse and may require the consent of the Environment Agency. No surface water is allowed to be discharged to the public sewerage system.

Water

A water supply can be made available to this development. However, our water mains may need extending to serve any development on this site. The applicant, who may be required to pay a capital contribution, will need to sign an Agreement under Sections 41, 42 & 43 of the Water Industry Act 1991.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999. Water pressure in this area is regulated to around 20metres head. This should be taken into account when designing the internal plumbing.

The applicant must undertake a complete soil survey, as and when land proposals have progressed to a scheme design i.e. development, and results submitted along with an application for water. This will aid in our design of future pipework and materials to eliminate the risk of contamination to the local water supply.

General

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers.