

Ribble Valley Borough Council
Council Officers, Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2013/0981
Our ref: DC/13/4465
Date: 06-JAN-14

Dear Sir/Madam,

Location : Land at Chatburn Road Clitheroe
Proposal : Residential development 20 dwellings, 3 care apartments and 60 bed care home all matters reserved

With reference to the above planning application.

Wastewater

I will have no objection to the proposal provided that the following conditions are met: -

- Notwithstanding any indication on the approved plans, no development approved by this permission shall commence until a scheme for the disposal of foul and surface waters for the entire site has been submitted to and approved in writing by the Local Planning Authority. For the avoidance of doubt, surface water must drain separate from the foul and no surface water will be permitted to discharge directly or indirectly into existing sewerage systems. The development shall be completed, maintained and managed in accordance with the approved details.

Reason: To ensure a satisfactory form of development and to prevent an undue increase in surface water run off and to reduce the risk of flooding

Water

A water supply can be made available to the proposed development.

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

General

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 7462200 regarding connection to the water mains/public sewers.

United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 7510101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development .

Are you aware that we offer a number of services to support the planning & construction of a new development? Further information on water and wastewater developer services can be found at <http://www.unitedutilities.com/builders-developers.aspx>

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours faithfully

Lesley Johnson
United Utilities
Developer Services and Planning