



**United Utilities Water PLC  
Developer Services & Planning**

Warrington North WWTW  
Gatewath Street  
Warrington  
WA5 1DS

Telephone: 01925 679319  
Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council  
Council Offices  
Church Walk  
Clitheroe  
BB7 2RA

**Your ref:** 3/2013/1052  
**Our ref:** DC/14/116  
**Date:** 13-JAN-14

Dear Sir/Madam

**Location: Land adjacent to Whitecroft, Kayley Lane, Chatburn, BB7 4AX**  
**Proposal: Erect 1 No dwelling**

With reference to the above planning application,

United Utilities will have no objection to the proposed development,

### **Drainage**

If possible this site should be drained on a separate system, with only foul drainage connected into the foul sewer. Surface water should discharge to the soakaway/watercourse/surface water sewer and may require the consent of the Local Authority. If surface water is allowed to be discharged to the public surface water sewerage system we may require the flow to be attenuated to a maximum discharge rate determined by United Utilities.

### **Water**

A separate metered supply to each unit will be required at the applicant's expense and all internal pipework must comply with current water supply (water fittings) regulations 1999.

Should this planning application be approved, the applicant should contact our Service Enquiries on 0845 746 2200 regarding connection to the water mains/public sewers.

### **General**

United Utilities offer a fully supported mapping service at a modest cost for our water mains and sewerage assets. This is a service, which is constantly updated by our Property Searches Team (Tel No: 0870 751 0101). It is the applicant's responsibility to demonstrate the exact relationship between any assets that may cross the site and any proposed development.

Are you aware that we offer a number of services to support the planning & construction of a new development? Further information on water and wastewater developer services can be found at <http://www.unitedutilities.com/builders-developers.aspx>.

Please note, due to the public sewer transfer, not all sewers are currently shown on the statutory sewer records, if a sewer is discovered during construction, please contact a Building Control Body to discuss the matter further.

Yours faithfully,

Jamie Riding  
Developer Services & Asset Protection  
United Utilities