



**United Utilities Water Limited  
Developer Services & Planning**  
Warrington North WWTW  
Barnard Street off Old Liverpool Road  
Gatewarth Industrial Estate  
Sankey Bridges  
Warrington  
WA5 1DS

Telephone : 01925 679371  
Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council  
Council Offices  
Church Walk  
Clitheroe  
BB7 2RA

**Your ref:** 3/2014/1115  
**Our ref:** DC/15/198  
**Date:** 28-JAN-15

Dear Sir/Madam,

**Location: land off Parsonage Avenue Ribchester PR3 3ZH**  
**Proposal: Variation of Condition 10 on planning app 3/2014/0624**

United Utilities have no objection to the variation in condition to the following:

This site must be drained on a separate systems combining just prior to connection to the public combined sewerage system. Surface water discharging to the sewerage system must be attenuated to a maximum discharge rate of 5 l/s.

United Will only permit highway drainage from within the boundary of the scheme.

Yours faithfully

Gareth Hindley  
United Utilities  
Developer Services and Planning