



**United Utilities Water Limited
Developer Services & Planning**
Warrington North WWTW
Barnard Street off Old Liverpool Road
Gatewarth Industrial Estate
Sankey Bridges
Warrington
WA5 1DS

Telephone : 01925 679371
Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council
Council Offices
Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2015/0355
Our ref: DC/15/1621
Date: 27/05/2015

Dear Sir/Madam,

Location: Land off Parsonage Ave, Ribchester
Proposal: Discharge Of Condition 1-Surface Water Drainage

With reference to the above planning application, United Utilities unfortunately cannot discharge the condition as the developer intends to drain highway drainage from the existing highway into the public sewer and United Utilities have no responsibility to accept this.

Yours faithfully

Rebecca Pemberton
United Utilities
Developer Services and Planning