

Phone: 01772 534593

Email: chris.dunderdale@lancashire.gov.uk

Date: 22 March 2016

APPLICATION CONSULTATION RESPONSE

| | |
|----------------------------|---|
| Application Number: | 3/2016/0193 |
| Location: | Land East of Chipping Lane, Longridge |
| Proposal: | Application for the detailed approval of appearance, landscaping, layout and scale for the erection of 118 dwellings (Phase 1) pursuant to outline consent 3/2014/0764 for the development of up to 363 homes including affordable housing and housing for the elderly, relocation of Longridge Cricket Club to provide a new cricket ground, pavilion, car park and associated facilities, new primary school, vehicular and pedestrian access landscaping and public open space, with all matters reserved except for access. |

Thank you for inviting the Lead Local Flood Authority (LLFA) to comment on the above application. The Flood and Water Management Act (FWMA) 2010 introduces a range of new powers, duties and responsibilities and makes Lancashire County Council a Lead Local Flood Authority (LLFA). The Flood and Water Management Act 2010 sets out the requirement for LLFAs to manage 'local' flood risk within their area. 'Local' flood risk refers to flooding or flood risk from surface water, groundwater or from ordinary watercourses.

Comments provided in this representation, including conditions, are advisory and it is the decision of the Local Planning Authority (LPA) whether any such recommendations are acted upon. It is ultimately the responsibility of the Local Planning Authority to approve, or otherwise, any drainage strategy for the associated development proposal.

The comments given have been composed based on the current extent of the knowledge of the LLFA and information provided at the time of this response.

Sustainable Drainage Systems:

[Paragraph 103 of the National Planning Policy Framework \(NPPF\)](#) and [Written Statement on Sustainable Drainage Systems \(HCWS161\)](#) requires that surface water arising from a developed site should, as far as it is practicable, be managed in a sustainable manner to mimic surface water flows arising from the site prior to the proposed development, whilst reducing flood risk to the site itself and elsewhere, taking climate change into account.

The Lead Local Flood Authority encourages that site surface water drainage is designed in line with the [Non-Statutory Technical Standards for Sustainable Drainage Systems](#) and [Planning Practice Guidance](#), including restricting developed discharge of surface water to greenfield runoff rates making suitable allowances for climate change and urban creep, managing surface water as close to the surface as possible and prioritising infiltration as a means of surface water disposal where possible.

Regardless of the site's status as greenfield or brownfield land, the Lead Local Flood Authority encourages that surface water discharge from the developed site should be as close to the greenfield runoff rate as is reasonably practicable in accordance with Standard 2 and Standard 3 of the [Non-Statutory Technical Standards for Sustainable Drainage Systems](#).

Sustainable drainage systems offer significant advantages over conventional piped drainage systems in reducing flood risk by attenuating the rate and quantity of surface water run-off from a site, promoting groundwater recharge absorbing diffuse pollutants and improving water quality. Ponds, reedbeds and seasonally flooded grasslands can be particularly attractive features within public open space.

The wide variety of available sustainable drainage techniques means that virtually any development should be able to include a scheme based around these principles and provide multiple benefits, reducing costs and maintenance needs.

The applicant is reminded that Paragraph 103 of the NPPF requires priority use to be given to SuDS and in accordance with Paragraph 80, Section 10 of the Planning Practice Guidance the preferred means of surface water drainage for any new development is via infiltration. The applicant must submit evidence as to why each 'level' of this hierarchy cannot be achieved.

Prior to designing site surface water drainage for the site, a full ground investigation should be undertaken to fully explore the option of ground infiltration to manage the surface water in preference to discharging to a surface water body, sewer system or other means. For example, should the applicant intend to use a soakaway, they should be shown to work through an appropriate assessment carried out under Building Research Establishment (BRE) Digest 365.

The Lead Local Flood Authority also strongly encourages that the developer should take into account designing drainage systems for exceedance working with the natural topography for the site. Should exceedance routes be used, the applicant must provide a site layout plan with these displayed, in line with Standard 9 of DEFRA's Technical Standards for SuDS

Flow balancing SuDS methods which involve the retention and controlled release of surface water from a site may be an option for some developments at a scale where uncontrolled surface water flows would otherwise exceed the local greenfield run off rate. Flow balancing should seek to achieve water quality and amenity benefits as well as managing flood risk

Further information on SuDS can be found in;

CIRIA C687 – Planning for SuDS – Making it Happen

CIRIA C697 – The SuDS manual

CIRIA C635 - Designing for exceedance in urban drainage: good practice

CIRIA C698 – Site handbook for the construction of SUDS

HR Wallingford SR 666 - Use of SuDS in high density developments

National Planning Policy Framework and Planning Practice Guidance

The multifunctional potential of sustainable drainage systems (SuDS) should be exploited to maximise their cost effectiveness, regardless of the size of development site. Early design consideration is advised to build SuDS into multi-functional spaces and build up a network of SuDS that manage runoff close to its source to avoid the need for large storage areas.

Designing green space and public realm with SuDS that work well when both wet and dry can provide valuable community recreational space as well as important blue and green infrastructure. Sports pitches, squares, courtyards, playgrounds, landscapes around buildings, urban parks, green corridors and woodlands are all popular types of open space which can be integrated with SuDS. SuDS can also contribute to development targets for open space where they are designed to be multi-functional.

On smaller development sites, space efficient SuDS can still be incorporated and include, for example, green roofs, bioretention gardens, permeable paving, rills, rainwater harvesting, hardscape storage, micro-wetlands, and bioretention tree pits.

Land Drainage Consent

Under the Land Drainage Act 1991 (as amended by the Flood & Water Management Act 2010), you need consent from the Lead Local Flood Authority if you want to build a culvert or structure (such as a weir) or carry out works within the banks of any

ordinary watercourse which may alter or impede the flow of water, regardless of whether the watercourse is culverted or not.

As a minimum, the applicant will be expected to:

- Carry out studies of the existing culvert/watercourse condition and capacity;
- Undertake an examination of the downstream condition and implications of the development proposal, and;
- Restrict discharge rates so that the peak runoff rate from the development to the ordinary watercourse for the 1 in 1 year rainfall event and the 1 in 100 year rainfall event should never exceed the peak greenfield runoff rate for the same event.

As per Lancashire County Council Consenting and Enforcement Policy, it should be noted that the Lead Local Flood Authority will generally refuse consent applications which seek to culvert an existing ordinary watercourse. This is in line with Environment Agency guidance on protecting watercourses: <http://evidence.environment-agency.gov.uk/FCERM/en/FluvialDesignGuide/Chapter8.aspx?pagenum=6>

You should contact the Flood Risk Management Team at Lancashire County Council to obtain Land Drainage Consent. Information on the application process and relevant forms can be found here: <http://new.lancashire.gov.uk/roads-parking-and-travel/roads/flooding/alterations-to-a-watercourse.aspx>

For the avoidance of doubt, once planning permission has been obtained it does not mean that land drainage consent will be given.

Request for consultation on discharge of a condition the LLFA recommends

The Lead Local Flood Authority asks to be consulted on the details submitted for approval to your Authority to discharge Condition 8 of Outline approval 3/2014/0764 and on any subsequent amendments/alterations. A copy of Condition 8 has been included below for reference:

Condition 8 Ref 3/2014/0764 Decision notice:

The drainage strategy shall accord with the approved Flood Risk Assessment and Drainage Appraisal (Ref: 880500 R1 (03), dated March 2015) and shall demonstrate that the surface water run-off generated by the 1 in 100 year plus climate change critical storm shall not exceed the run-off from the undeveloped site and shall not increase the risk of flooding off-site. Surface water discharge from the developed site should be limited to 7.3l/s/ha

(Greenfield QBar). Prior to the commencement of development within a phase, the details of a scheme for surface water drainage and means of disposal for that phase, to accord with the Drainage Strategy approved and to include evidence of an assessment of site conditions, sustainable drainage principles, an assessment of the hydrological and hydro-geological context of the development, management and maintenance and timescales for implementation, shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall be implemented, maintained and managed in accordance with the approved details at all times thereafter.

REASON: To ensure satisfactory storage and disposal of surface water from the site to prevent flooding in accordance with Policies DMG1 and DME6 and Key Statement EN2 of the Ribble Valley Core Strategy.

Lead Local Flood Authority Position - No Objection

The Lead Local Flood Authority has **no objection** to this reserved matters application; however we note that the requirements of Condition 8 of Outline approval 3/2014/0764 have not yet been satisfied. Ribble Valley Borough Council and the applicant are reminded that the proposals for layout and landscaping directly impact the nature of any proposed sustainable drainage scheme.

If there are any material changes to the submitted information which impact on surface water, the local planning authority is advised to consider re-consulting the LLFA.

Please send a copy of the decision notice to: suds@lancashire.gov.uk

Yours faithfully,

Chris Dunderdale
Lead Local Flood Authority

