

Ribble Valley Borough Council
Church Walk,
Clitheroe,
BB7 2RA

Phone: 0300 123 6780
Email: lhscustomerservice@lancashire.gov.uk
Your ref:
Our ref: LHS/CS/3/2016/0659
Date: 8th August 2016

For the attention of Adam Birkett

Proposal:	Amendment of approved proposed access gates and gateposts to include new capping detail and stone flanking walls
Location:	The Eaves Pendleton Road Wiswell BB7 9BZ
Grid Ref:	375152 - 438114

With regard to your letter dated the 25th July 2016

The Highway Development Control Section is of the opinion that the shown sight lines are incorrect as they should be to the near side kerb line and not the centre of the road.

The maximum height of any hedge wall etc within the sight line to be a maximum of 1.0m high.

If you have any questions please do not hesitate to contact me.

Yours sincerely

Stewart Gailey
Highway Development Control Engineer