
Les Gooding Design Ltd. **Structural and Civil Engineering Consultants**

10 St. Chad's Avenue, Chatburn
Clitheroe, Lancs. BB7 4AN
lesgooding@btconnect.com

Tel. 01200 440322
Mob. 07793 389298

Company number 04525545

27th June 2016

Simon Cherry
Cherry Hall
Grindleton
Clitheroe BB7 4QT

Dear Simon

Re:- Large Tree In The Garden at the Rear Of Cherry Hall, Grindleton

I confirm that I have inspected the situation regarding the large tree located in the garden area at the rear of your property in the last few days and confirm that I view this as having a potential danger to collapse and injuring anyone using the garden at that time.

The tree is located close to the boundary wall between the garden and the access road to other properties. This wall acts as a retaining wall, the level of the garden being approximately one metre higher than the roadway and is already showing signs of distress in the stonework due to the presence of the tree.

The tree is noticeably leaning over, away from the wall in a southerly direction and is decidedly lopsided with the weight of the upper branches increasing the moment and potential of the tree to topple over.

Under the circumstances, I strongly recommend that this tree be removed as I consider it to be a potential danger to you, your family and the general public at large.

Yours sincerely



Les Gooding

