

Phone: 0300-123-6780
Email: Suds@lancashire.gov.uk

Date: 26 August 2016

APPLICATION CONSULTATION RESPONSE

Application Number:	3/2016/0691
Location:	Jacksons Haulage Salthill Industrial Estate Lincoln Way Clitheroe BB7 1QD
Proposal:	Erection of two B1 workshop/light industrial units

Thank you for inviting the Lead Local Flood Authority (LLFA) to comment on the above application. The Flood and Water Management Act 2010 sets out the requirement for LLFAs to manage 'local' flood risk within their area. 'Local' flood risk refers to flooding or flood risk from surface water, groundwater or from ordinary watercourses.

Comments provided in this representation, including conditions, are advisory and it is the decision of the Local Planning Authority (LPA) whether any such recommendations are acted upon. It is ultimately the responsibility of the Local Planning Authority to approve, or otherwise, any drainage strategy for the associated development proposal. The comments given have been composed based on the current extent of the knowledge of the LLFA and information provided with the application at the time of this response.

Lead Local Flood Authority Position

In the absence of adequate information to assess the principle of surface water drainage associated with the proposed development, **the LLFA objects** to this application and recommend refusal of planning permission until further information has been submitted to the local planning authority, in consultation with the LLFA.

The proposed scale of development may present risks of flooding on-site and/or off-site if surface water run-off is not effectively managed. The lack of any information at all in relation to surface water drainage means the LLFA cannot assess whether the development proposal meets the requirements of Paragraph 103 of the NPPF or Paragraph 80 of Section 10 of the PPG in principle.

The submission of basic information on how surface water is intended to be managed is vital if the local planning authority is to make informed planning decisions. In the absence of any information at all regarding surface water

management, the flood risks resulting from the proposed development are unknown and this is therefore sufficient reason in itself for a refusal of planning permission.

Overcoming our objection

The applicant may overcome our objection by submitting information which demonstrates how surface water will be managed on site, satisfying the principles of Paragraph 103 of the NPPF and Paragraph 80 of Section 10 of the PPG.

If this cannot be achieved we will consider whether there is a need to maintain our objection to the application. Production of this information will not in itself result in the removal of an objection.

We ask to be re-consulted following the submission of additional information addressing surface water drainage proposals. We will provide you with comments within 21 days of receiving formal re-consultation. Our objection will be maintained until an adequate level of information has been submitted which satisfies the principles outlined above.

Yours faithfully,

Dianne Taylor

Lead Local Flood Authority