

**Phone:** 01772 534593

**Email:** Chris.dunderdale@lancashire.gov.uk

**Date:** 13 December 2016

## APPLICATION CONSULTATION RESPONSE

<b>Application Number:</b>	3/2016/0990
<b>Location:</b>	Land to the North of Ribblesdale View Chatburn BB7 4BB
<b>Proposal:</b>	Outline application for the erection of 18 dwellings (all matters reserved except for access).

Thank you for inviting the Lead Local Flood Authority (LLFA) to comment on the above application. The Flood and Water Management Act 2010 sets out the requirement for LLFAs to manage 'local' flood risk within their area. 'Local' flood risk refers to flooding or flood risk from surface water, groundwater or from ordinary watercourses.

Comments provided in this representation, including conditions, are advisory and it is the decision of the Local Planning Authority (LPA) whether any such recommendations are acted upon. It is ultimately the responsibility of the Local Planning Authority to approve, or otherwise, any drainage strategy for the associated development proposal. The comments given have been composed based on the current extent of the knowledge of the LLFA and information provided with the application at the time of this response.

### **Lead Local Flood Authority (LLFA) Position**

The Lead Local Flood Authority **objects** to the development proposal on the following basis:

#### **Objection 1:**

**Inadequate information to assess application** - In the absence of adequate information to assess the principle of surface water drainage associated with the proposed development, we object to this application and recommend refusal of planning permission until further information has been submitted to the local planning authority.

**Reason:** The proposed scale of development may present risks of flooding on-site and/or off-site if surface water run-off is not effectively managed. The lack of any information at all in relation to surface water drainage means the LLFA cannot assess whether the development proposal meets the requirements of Paragraph 103 of the National Planning Policy Framework or Paragraph 80 of Section 10 of the Planning Practice Guidance in principle.

The submission of basic information on how surface water is intended to be managed is vital if the local planning authority is to make informed planning decisions. In the absence of any information at all regarding surface water management, the flood risks resulting from the proposed development are unknown and this is therefore sufficient reason in itself for a refusal of planning permission. The table below highlights the additional information which would be required in order for the LLFA to be able to provide a substantive response:

**Desktop study to incorporate maps showing:**

- Topography of the development site, with contours at 1m intervals
- Existing surface water flow routes, drains, sewers and watercourses
- Flood risk from main river and coastal sources
- Surface water and groundwater flood risk
- Geological and soil types

**Indicative Site Drainage Strategy, including:**

- Preliminary sustainable drainage proposals
- Outfall locations
- Discharge rates
- On-site storage requirements

**Overcoming our objection:**

You can overcome our objection by submitting information which demonstrates how surface water will be managed on site, satisfying the principles of Paragraph 103 of the NPPF and Paragraph 80 of Section 10 of the PPG. If this cannot be achieved we will consider whether there is a need to maintain our objection to the application. Production of this information will not in itself result in the removal of an objection.

Advice and information regarding surface water drainage can be found in our Pre-Application Standing Advice:

- <http://www.lancashire.gov.uk/media/657248/LLFA-Standing-Pre-Application-Advice.pdf>

We ask to be re-consulted following the submission of additional information. We will then provide you with comments within 21 days of receiving formal re-consultation.

Yours faithfully,

**Chris Dunderdale**  
Lead Local Flood Authority