



**United Utilities Water Limited  
Developer Services & Planning**  
Warrington North WWTW  
Gatewath Industrial Estate  
Barnard Street off Old Liverpool Road  
Sankey Bridges  
Warrington  
WA5 1DS

Telephone : 01925 679333  
Planning.liaison@uuplc.co.uk

**Your ref:** 3/2017/0232  
**Our ref:** DC/17/1198  
**Date:** 10-APR-17

Ribble Valley Borough Council  
Council Offices, church Walk  
Clitheroe  
BB7 2RA

Dear Sir/Madam,

**Location: Land East of Chipping Lane, Longridge**

**Proposal: Variation of Condition 8 (drainage strategy) of planning 3/2014/0764**

United Utilities are unsure what the variation is to the wording of condition 8, if it's simply to replace the old FRA and discharge rate of 7.x l/s to the new FRA and the revised figure of 8.3 l/s/ha United Utilities can agree to the variation.

The applicant can discuss any of the above with Developer Engineer, **Graham Perry**, by email at [wastewaterdeveloperservices@uuplc.co.uk](mailto:wastewaterdeveloperservices@uuplc.co.uk).

Yours faithfully

Tracy Churchman  
United Utilities  
Developer Services and Planning