

**Subject:** RE: Hambledon View  
**From:** Younas, Mohammed (Mohammed.Younas@uuplc.co.uk)  
**To:** frank\_unsworth@yahoo.co.uk;  
**Date:** Wednesday, 15 March 2017, 15:43

Frank,

Thank you for the amended plan.

I will have no objection to the proposed development provided Part H4 of building Regulation is satisfied.

Redundant drains/sewer running under the development would require either grubbing out or filling with concrete.

No formal building over agreement is required in this instance.

Regards

**Mohammed Younas**

Developer services Inspector

Developer Services & Planning

United Utilities

**T:** 01925 537537 (internal 37537)

**M:** 07795 268306 (mobex 58953)

unitedutilities.com

**From:** Frank Unsworth [mailto:frank\_unsworth@yahoo.co.uk]  
**Sent:** 11 March 2017 21:14  
**To:** Younas, Mohammed <Mohammed.Younas@uuplc.co.uk>  
**Subject:** Re: Hambledon View

Thank you Mohammad,

I will amend the position of plot 3 and send you a revised plan the camera survey will also be ready on Monday for you.

Thanks for your help Mohammad.