



From: Craig Harrison [mailto:Craig.Harrison@sunderlandpeacock.com]
Sent: 24 September 2018 16:00
To: Jane Tucker
Cc: Chris Sullivan
Subject: RE: Invalid planning application 3/2018/0167 8 Spring Gardens, Clitheroe Road, Waddington BB7 3HH - Instructions for writing a Flood Risk Assessment

Dear Jane,

With regards to the Flood Risk Assessment we confirm the following:

The floor level of the proposed extension will be the same height as the existing house floor level.

We also confirm that the internal sockets within the extension will be raised to 900mm above floor level and the floor of the extension will be of solid construction.

Regards

Craig Harrison

BSc Hons Architectural Technology, HND Building Studies,
BTEC National Diploma Mechanical & Electrical Engineering

sunderland peacock and associates ltd.

hazelmere, pimlico road, clitheroe, lancashire, BB7 1AG
t 01200 423178 f 01200 427328