



**United Utilities Water Limited  
Developer Services & Planning**  
Warrington North WWTW  
Gatewarth Industrial Estate  
Barnard Street off Old Liverpool Road  
Sankey Bridges  
Warrington  
WA5 1DS

Telephone: 01925 679333  
[Planning.liaison@uuplc.co.uk](mailto:Planning.liaison@uuplc.co.uk)

**Your ref:** 3/2018/0183  
**Our ref:** DC/18/1268  
**Date:** 26-MAR-18

Ribble Valley Borough Council  
Council Offices, Church Walk  
Clitheroe  
BB7 2RA

Dear Sir/Madam,

**Location: Back St Pauls Street Low Moor Clitheroe BB7 2LS**  
**Proposal: Discharge of drainage condition**

We are unable to discharge the drainage condition because the applicant has not confirmed the rate of discharge that surface water will be restricted to nor have they confirmed the size of the attenuation tank

The applicant can discuss any of the above with **Developer Engineer, Graham Perry**, by email at [wastewaterdeveloperservices@uuplc.co.uk](mailto:wastewaterdeveloperservices@uuplc.co.uk).

Yours faithfully

Tracy Churchman  
United Utilities  
Developer Services and Planning