



**United Utilities Water Limited  
Developer Services & Planning**  
Warrington North WWTW  
Gatewath Industrial Estate  
Barnard Street off Old Liverpool Road  
Sankey Bridges  
Warrington  
WA5 1DS

Telephone: 01925 679333  
Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council  
Council Offices, Church Walk  
Clitheroe  
BB7 2RA

**Your ref:** 3/2018/0417  
**Our ref:** DC/18/2203  
**Date:** 04-JUN-18

Dear Sir/Madam,

**Location: Hare Hill Croft, Chatburn, Old Road, Chatburn**  
**Proposal: Discharge of drainage condition 6**

With reference to the above application, it's not clear where surface water will drain to nor is it clear what rate the applicant intends to restrict flows or if there is sufficient capacity in the surface water network to attenuate flows at that rate.

The applicant can discuss any of the above with **Developer Engineer, Graham Perry**, by email at [wastewaterdeveloperservices@uuplc.co.uk](mailto:wastewaterdeveloperservices@uuplc.co.uk).

Yours faithfully

Tracy Churchman  
United Utilities  
Developer Services and Planning