


Notes

1. This drawing is to be read in conjunction with the standard details, the layouts, schedules and specifications for the development.
2. A +1% gradient represents a rise of 1m in 100m.
3. Left and right hand channels are on the left and right hand side respectively, when standing at zero chainage and looking along the road.
4. Pipe sizes are stated in millimetres and levels are shown in metres A.O.D.
5. All pipes to have flexible joints with granular bedding (Class S) unless stated otherwise. Where 150mm concrete bed and surround is specified the concrete must be broken at the joint positions by the insertion of a 'flexcell' collar.
6. Connections to existing sewers are to be SOFFIT TO SOFFIT Unless noted otherwise.
7. All vitrified clay pipes to be EXTRA STRENGTH to B.S. 65. 1991.
8. Existing levels to be confirmed on site prior to commencement of works.
9. All concrete pipes to be CLASS 'M'.



STORMWATER COVER LEVEL	252.500	251.750	250.840	250.500	249.200	249.181	248.874
STORMWATER INVERT	251.150	250.283 250.283	249.453 249.453	249.137 247.741	247.700 247.700	247.547 247.562	247.562
STORMWATER DETAILS		Pipe 1.000 Dia 150 Circular CLAY 1 in 35 Strength 40kN/m Class S bed and surround	Pipe 1.001 Dia 150 Circular CLAY 1 in 35 Strength 40kN/m Class S bed and surround	Pipe 1.002 Dia 150 Circular CLAY 1 in 30 Strength 40kN/m Class S bed and surround	Pipe 1.003 Wavin Aquacell Units 35m ² x 0.8m deep to provide 28m ² of storage Strength 40kN/m	Pipe 1.004 Dia 150 Circular CLAY 1 in 80 Strength 40kN/m Class S bed and surround	Pipe 1.005 Dia 150 Circular CLAY 1 in 80 Strength 40kN/m Class S bed and surround
STORMWATER LENGTHS		30.330	29.047	9.479	16.284	12.274	3.585
FOULWATER COVER LEVEL	252.500	251.750	250.600	248.850		249.181	
FOULWATER INVERT	250.750	249.891 249.891	248.944 248.944	248.463 248.463		247.547	
		Pipe 1.000	Pipe 1.001	Pipe 1.002	Pipe 1.003		

A	Rev' to suit layout update	IH	IH
REV:	DESCRIPTION:	BY:	DATE:
STATUS: Construction			

S-Mech Ltd
Consulting Structural Engineering

7 Windsor Road
Chorley, Lancashire
PR7 1LN
01257 367 580
info@s-mech.co.uk

CLIENT: Pendle View Developments

PROJECT: Former Moorcock Inn

TITLE: Surface Water Long Section

SCALE AT A2: H1:500 V1:100	DATE: June 18	DRAWN: IH	CHECKED: IH
PROJECT NO: 2002	DRAWING NO: 04	REVISION: A	