

Development Control
Ribble Valley Borough Council

Phone: 0300 123 6780
Email: highways@lancashire.gov.uk

Your ref: 2018/0902
Our ref:
Date: 12/10/2018

Dear Sirs

Re: Planning Application 18/0902

Address: Longridge C of E Primary School Berry Lane Longridge PR3 3JA

Description: Installation of Securifor 2D Fencing including vehicular and pedestrian gates.

With respect to this application we would not wish to raise any objections.

Care should be taken to ensure that all pedestrian entrances are constructed in line with guidance from The Department of Transport's document Inclusive Mobility. This would indicate a wheelchair user and an accompanying adult would require a width of 1500mm, wherever possible this width should be used as the minimum requirement for any pedestrian access.

Should you wish to discuss the matter further, please do not hesitate to contact me by email or by telephone on 01772 531202.

Yours faithfully

Simon Hardie
Highways Development Control
Lancashire County Council

Phil Barrett
Director of Community Services
Cuerden Way • Bamber Bridge • Preston • PR5 6BS