

Nicola Gunn

From: McGill, Kathryn <Kathryn.McGill@cadentgas.com>
Sent: 17 November 2018 15:33
To: planning
Subject: Cadent and National Grid Plant Enquiry Response - Your Ref: 3/2018/0937 HI Our Ref: NW_TW_Z1_3NWP_013972-Planning-North
Attachments: NATIONAL_GRID_NW_TW_Z1_3NWP_013972_1_35656.pdf; 013972.pdf; SSW22.pdf
Follow Up Flag: Follow up
Flag Status: Completed
Categories: Yellow Category

Potential malicious content has automatically been removed from the attachment(s) and or body of this email. If any information is missing then please contact the IT Helpdesk to obtain the original attachments if required. Please note attachments are automatically deleted 5 days after delivery of this email.

Our Ref: NW_TW_Z1_3NWP_013972

Your Ref: 3/2018/0937 HI

Dear Sir/Madam,

Re: Grange Farm Parsonage Road Blackburn

Thank you for your recent communication regarding the above; I return a copy of drawings which show the approximate position/s of all known Cadent Gas gas mains and pipelines in the area of this application. Please note that individual 'service pipes' are not shown but their presence should be anticipated.

Cadent Gas has a **MAJOR ACCIDENT HAZARD PIPELINE** in the vicinity, **(indicated in orange)**.

This was laid to the appropriate standards and in accordance with the relevant codes of practice. The pipeline is laid in a legally negotiated easement to which certain conditions apply. The intended work is in the vicinity of our pipeline, which is laid in a legally negotiated easement to which certain conditions apply.

It is essential that access to the pipeline is not restricted, particularly in the event of an emergency. Therefore, there must be no obstructions within the pipeline's maintenance easement strip, which would limit or inhibit essential maintenance works on the pipeline.

The BPD (Building Proximity Distance) for the *Lostock Hall- New Inns* Pipeline is 8metres.

The BPD is taken from The Institution of Gas Engineers and Managers publication IGEM/TD/1 Edition 5 which is the standard applicable to steel pipelines and associated installations for high pressure gas transmission. This is the standard adopted by Cadent Gas and endorsed by the Health and Safety Executive (HSE).

There are other restraints imposed on high pressure gas pipelines, these are land use planning distances. These are distances defined by the HSE to allow them to advise on the acceptability of new developments next to the pipeline and are controlled through the HSE's Planning Advice for Developments near Hazardous Installations (PADHI) process. Further guidance on how these are applied can be found on the HSE's website <http://www.hse.gov.uk/landuseplanning/padhi.pdf>

Under Land Use Planning the HSE may wish to apply more stringent criteria for Building Proximity. I recommend that you ensure that they are formally consulted.

When working in the vicinity of **ANY** Cadent Gas pipelines, the standards set out in the enclosed copy of the National Grid specification **SSW22** must be strictly adhered to. **PLEASE ENSURE THAT THIS IS HANDED TO THE RESPONSIBLE PERSON ON SITE, TOGETHER WITH COPIES OF THE ENCLOSED PLANS.**

It is the responsibility of the applicant to contact Cadent Gas prior to any works commencing on site. As you will appreciate we are unable to provide specific guidance based on the information provided. It is therefore essential that the applicant should contact Cadent Gas at the earliest convenience providing detailed site plans, method statements and risk assessments. Correspondence should be forwarded to the above address and marked for the attention of 'The Plant Protection Team'. This will enable us to provide the relevant documentation for safe working in the vicinity of our pipeline, and to arrange appropriate site supervision.

Early Contact at the planning stage is very important to allow full discussion of proposals and to ensure the safety of plant and operators.

Plant Protection Team, 3rd Party Enquiries, National Grid Block 1 floor 2 Brick Kiln Street Hinckley Leicestershire LE10 ONA.

Please note that a minimum 7 days notice, or shorter if agreed with Cadent Gas, is required before any work may commence within the easement.

I trust that this information is to your satisfaction. Please let me know whether Cadent Gas can furnish you with any further information that may be of assistance to you in this matter.

Yours faithfully,

Kathryn McGill
Pipelines NW
Network Technician – RDOC

Cadent Gas Ltd
Mersey Road North, Failsworth, Manchester M35 9FF
M +44 (0)7967 311391
Kathryn.Mcgill@cadentgas.com

From: .box.PPRSTeam
Sent: 01 November 2018 10:29
To: .Box.SiteVisits
Subject: FW: EXT || Cadent and National Grid Plant Enquiry Response - Your Ref: 3/2018/0937 HI Our Ref: NW_TW_Z1_3NWP_013972

I have given him feedback for the overcapture.

Not need to reprocess as the lhp would still be affected.

Warm Regards,

Kayleigh

Kayleigh Betterton
Plant Protection Process Co-ordinator
Customer Centre - Customer Performance

Cadent
Brick Kiln Street,
Hinckley, Leicestershire
LE10 ONA
T 0800 688 588
plantprotection@cadentgas.com
cadentgas.com

Self Service for Plant Enquiries:

www.beforeyoudig.nationalgrid.com

From: Cadent EAGLES System [mailto:eaglessupport.software@dnvgl.com]

Sent: 31 October 2018 14:29

To: .box.PPRSTeam

Subject: EXT || Cadent and National Grid Plant Enquiry Response - Your Ref: 3/2018/0937 HI Our Ref: NW_TW_Z1_3NWP_013972

Formal Planning Application - Your Ref: 3/2018/0937 HI Our Ref: NW_TW_Z1_3NWP_013972

Thank you for your enquiry which was received on 19/10/2018.

Please refer to the attached documentation for Cadent and National Grid's response.

Self-service for Plant Enquiries: www.beforeyoudig.nationalgrid.com

If you need to contact the Plant Protection Team regarding your enquiry, please use the following details:

Email: plantprotection@cadentgas.com

Address: Plant Protection
Cadent
Block 1; Floor 1;
Brick Kiln Street
Hinckley
LE10 0NA

Telephone: +44 (0)800 688 588

National Gas Emergency Number:

0800 111 999*

National Grid Electricity Emergency Number:

0800 40 40 90*

* Available 24 hours, 7 days/week. Calls may be recorded and monitored.

***** This e-mail and any files transmitted with it, are confidential and are intended solely for the use of the individual or entity to whom they are addressed. If you have received this e-mail in error, please reply to this message and let the sender know.

This e-mail, and any attachments are strictly confidential and intended for the addressee(s) only. The content may also contain legal, professional or other privileged information. If you are not the intended recipient, please notify the sender immediately and then delete the e-mail and any attachments. You should

not disclose, copy or take any action in reliance on this transmission.

Please ensure you have adequate virus protection before you open or detach any documents from this transmission. Cadent Gas Limited does not accept any liability for viruses. An e-mail reply to this address may be subject to monitoring for operational reasons or lawful business practices.

Cadent Gas Limited is a limited liability company, registered in England and Wales (registered no. 10080864) with its registered office at Ashbrook Court, Prologis Park, Central Boulevard, Coventry CV7 8PE.
