

Ribble Valley Borough Council
Development Control
Council Offices Church Walk
Clitheroe
Lancashire
BB7 2RA

Our ref: NO/2019/111800/01-L01
Your ref: 3/2019/0484
Date: 01 July 2019

Dear Sir/Madam

**EXTENSION TO EXISTING WORKSHOP AND CREATION OF PARKING AREA.
JAMES ALPE LIMITED, LINCOLN WAY, CLITHEROE, LANCASHIRE, BB7 1QD.**

Thank you for consulting us on the above application which we received on 7 June 2019.

Environment Agency position

We object to this application as it involves building works within 8 metres of a Main River watercourse, Mearley Brook, in an area which is within a floodplain.

Reasons

- The proposed development would infill the floodplain and obstruct flood flows, thereby increasing the risk of flooding to surrounding areas.
- The underside of the proposed bridge would need to be at least 600mm above the 1 in 100 year flood level, which would be unachievable.
- The proposed development would restrict essential maintenance and emergency access to the watercourse. The permanent retention of a continuous unobstructed area is an essential requirement for future maintenance and/or improvement works.

Environmental permit - advice to applicant

The Environmental Permitting (England and Wales) Regulations 2016 require a permit to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culvert (16 metres if tidal)
- on or within 16 metres of a sea defence
- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in a floodplain more than 8 metres from the river bank, culvert or flood defence structure (16 metres if it's a tidal main river) and you don't already have planning permission.

In this particular instance, it is unlikely that we would be able to issue a permit for these proposals.

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03702 422 549. The applicant should not assume that a permit will automatically be forthcoming

Environment Agency
Lutra House Walton Summit, Bamber Bridge, Preston, PR5 8BX.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

The Environment Agency has a right of entry to the Mearley Brook main river by virtue of Section 172 of the Water Resources Act 1991, and a right to carry out maintenance and improvement works by virtue of Section 165 of the same Act.

Yours faithfully

Carole Woosey
Planning Advisor

E-mail - clplanning@environment-agency.gov.uk