

Nicola Gunn

From: planning
To: Nicola Clark
Subject: RE: MH-205 - Clitheroe Golf Club Driving Range plots 190821.pdf

-----Original Message-----

From: Nicola Clark
Sent: 06 September 2019 17:23
To: Rebecca Bowers; planning
Cc: Ken Robinson
Subject: FW: MH-205 - Clitheroe Golf Club Driving Range plots 190821.pdf

Dear Rebecca,

I have reviewed the attached lighting assessment. Although I have no objections to the lighting scheme going ahead, I would ask that the undernoted condition is made.

The design of the external lighting associated with the development hereby approved shall ensure that light intrusion into the windows of the nearest sensitive premises will not exceed 5 lux before 23.00, and 1 lux after 23.00 (Environmental Zone E2), as described in the Institution of Lighting Professionals' Guidance Notes for the Reduction of Obtrusive Light GN01:2011 (or any subsequent replacement guidance).

Reason: To safeguard residential amenity and in the interests of public safety in accordance with Policy

Kind regards,

Nicola