


Environmental Health Consultation Response		Officer	Nicola Clark
Detail: Erection of business units (use class B1 and B8) comprising three new		Flare SRU:	042056
Address:	Lower Road Longridge Preston Lancashire PR3 2YY		 Ribble Valley Borough Council www.ribblevalley.gov.uk
Application Ref:	3/2019/0666	Case Officer:	
Response Ref:	3/2019/0666/ENV/01	Issue Date:	
			Mr Adam Birkett 20 August 2019

General Comments/Observations	
<p>Dear Adam,</p> <p>I have reviewed the above noted planning application and would advise you that I wish to see a full noise impact assessment to assess the impact of the proposed noise sources on the nearest noise sensitive premises (to include any dwellings granted planning permission but not yet built).</p> <p>The noise impact assessment shall be carried out in accordance with the main procedural requirements of <i>British Standard 4142:2014 Methods for rating and assessing industrial and commercial sound</i>. An assessment of the background ($L_{A90,T}$) and residual ($L_{Aeq,T}$) noise shall be required to quantify the nature and levels of background noise at the nearest noise sensitive premises.</p> <p>In addition to the above, the assessment shall include the highest evening 19.00-23.00) and night-time (23.00-07.00) L_{Amax} of the proposed noise sources at the nearest noise sensitive premises.</p> <p>Please note that any assessment shall be carried out for the most sensitive hours within the time period applied for. It is recommended that the methodology for any assessment be submitted to me in writing prior to any assessment taking place.</p> <p>Kind regards,</p> <p>Nicola</p>	
<div></div>	
	Officer: Nicola Clark