



**United Utilities Water Limited
Developer Services & Metering**
2nd Floor, Grasmere House
Lingley Mere Business Park
Lingley Green Avenue
Warrington
WA5 3LP

Planning.liaison@uuplc.co.uk

Ribble Valley Borough Council
Council Offices, Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2019/1030
Our ref: DC/19/4912
Date: 03-DEC-19

Dear Sir/Madam,

Location: Land at former golf driving range Lincoln Way Clitheroe BB7 1QD
Proposal: Erection of 3 light industrial units and associated parking

With regards to the above development proposal, United Utilities Water Limited ('United Utilities') wishes to provide the following comments.

Drainage

In accordance with the National Planning Policy Framework (NPPF) and the National Planning Practice Guidance (NPPG), the site should be drained on a separate system with foul water draining to the public sewer and surface water draining in the most sustainable way.

We request the following drainage conditions are attached to any subsequent approval to reflect the above approach detailed above:

Condition 1 – Surface water

No development shall commence until a surface water drainage scheme has been submitted to and approved in writing by the Local Planning Authority. The drainage scheme must include:

- (i) An investigation of the hierarchy of drainage options in the National Planning Practice Guidance (or any subsequent amendment thereof). This investigation shall include evidence of an assessment of ground conditions and the potential for infiltration of surface water;***
- (ii) A restricted rate of discharge of surface water agreed with the local planning authority (if it is agreed that infiltration is discounted by the investigations); and***
- (iii) A timetable for its implementation.***

The approved scheme shall also be in accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacement national standards.

The development hereby permitted shall be carried out only in accordance with the approved drainage scheme.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution.

Condition 2 – Foul water

Foul and surface water shall be drained on separate systems.

Reason: To secure proper drainage and to manage the risk of flooding and pollution.

The applicant can discuss any of the above with Developer Engineer, **Thomas Bethell**, by email at wastewaterdeveloperservices@uuplc.co.uk.

Please note, United Utilities are not responsible for advising on rates of discharge to the local watercourse system. This is a matter for discussion with the Lead Local Flood Authority and / or the Environment Agency (if the watercourse is classified as main river).

If the applicant intends to offer wastewater assets forward for adoption by United Utilities, the proposed detailed design will be subject to a technical appraisal by an Adoptions Engineer as we need to be sure that the proposal meets the requirements of Sewers for Adoption and United Utilities' Asset Standards. The detailed layout should be prepared with consideration of what is necessary to secure a development to an adoptable standard. This is important as drainage design can be a key determining factor of site levels and layout. The proposed design should give consideration to long term operability and give United Utilities a cost effective proposal for the life of the assets. Therefore, should this application be approved and the applicant wishes to progress a Section 104 agreement, we strongly recommend that no construction commences until the detailed drainage design, submitted as part of the Section 104 agreement, has been assessed and accepted in writing by United Utilities. Any works carried out prior to the technical assessment being approved is done entirely at the developers own risk and could be subject to change.

Management and Maintenance of Sustainable Drainage Systems

Without effective management and maintenance, sustainable drainage systems can fail or become ineffective. As a provider of wastewater services, we believe we have a duty to advise the Local Planning Authority of this potential risk to ensure the longevity of the surface water drainage system and the service it provides to people. We also wish to minimise the risk of a sustainable drainage system having a detrimental impact on the public sewer network should the two systems interact. We therefore recommend the Local Planning Authority include a condition in their Decision Notice regarding a management and maintenance regime for any sustainable drainage system that is included as part of the proposed development.

For schemes of 10 or more units and other major development, we recommend the Local Planning Authority consults with the Lead Local Flood Authority regarding the exact wording of any condition. You may find the below a useful example:

Prior to occupation of the development a sustainable drainage management and maintenance plan for the lifetime of the development shall be submitted to the local planning authority and agreed in writing. The sustainable drainage management and maintenance plan shall include as a minimum:

- a. *Arrangements for adoption by an appropriate public body or statutory undertaker, or, management and maintenance by a resident's management company; and*
- b. *Arrangements for inspection and ongoing maintenance of all elements of the sustainable drainage system to secure the operation of the surface water drainage scheme throughout its lifetime.*

The development shall subsequently be completed, maintained and managed in accordance with the approved plan.

Reason: To ensure that management arrangements are in place for the sustainable drainage system in order to manage the risk of flooding and pollution during the lifetime of the development.

Please note United Utilities cannot provide comment on the management and maintenance of an asset that is owned by a third party management and maintenance company. We would not be involved in the discharge of the management and maintenance condition in these circumstances.

Water Supply

If the applicant intends to obtain a water supply from United Utilities for the proposed development, we strongly recommend they engage with us at the earliest opportunity. If reinforcement of the water network is required to meet the demand, this could be a significant project and the design and construction period should be accounted for.

To discuss a potential water supply or any of the water comments detailed above, the applicant can contact the team at [**DeveloperServicesWater@uuplc.co.uk**](mailto:DeveloperServicesWater@uuplc.co.uk).

Please note, all internal pipework must comply with current Water Supply (water fittings) Regulations 1999.

United Utilities' Property, Assets and Infrastructure

A public sewer crosses this site and we may not permit building over it. We will require an access strip width of six metres, three metres either side of the centre line of the sewer which is in accordance with the minimum distances specified in the current issue of "Sewers for Adoption", for maintenance or replacement. Therefore a modification of the site layout, or a diversion of the affected public sewer at the applicant's expense, may be necessary. To establish if a sewer diversion is feasible, the applicant must discuss this at an early stage with our Developer Engineer at wastewaterdeveloperservices@uuplc.co.uk as a lengthy lead in period may be required if a sewer diversion proves to be acceptable.

Deep rooted shrubs and trees should not be planted in the vicinity of the public sewer and overflow systems.

Where United Utilities' assets exist, the level of cover to the water mains and public sewers must not be compromised either during or after construction.

For advice regarding protection of United Utilities assets, the applicant should contact the teams as follows:

Water assets – DeveloperServicesWater@uuplc.co.uk

Wastewater assets – WastewaterDeveloperServices@uuplc.co.uk

It is the applicant's responsibility to investigate the possibility of any United Utilities' assets potentially impacted by their proposals and to demonstrate the exact relationship between any United Utilities' assets and the proposed development.

A number of providers offer a paid for mapping service including United Utilities. To find out how to purchase a sewer and water plan from United Utilities, please visit the Property Searches website; <https://www.unitedutilities.com/property-searches/>

You can also view the plans for free. To make an appointment to view our sewer records at your local authority please contact them direct, alternatively if you wish to view the water and the sewer records at our Lingley Mere offices based in Warrington please ring [0370 751 0101](tel:03707510101) to book an appointment.

Due to the public sewer transfer in 2011, not all sewers are currently shown on the statutory sewer records and we do not always show private pipes on our plans. If a sewer is discovered during construction; please contact a Building Control Body to discuss the matter further.

Should this planning application be approved the applicant should contact United Utilities regarding a potential water supply or connection to public sewers. Additional information is available on our website <http://www.unitedutilities.com/builders-developers.aspx>

Yours faithfully

Tracy Churchman
United Utilities
Developer Services and Metering