

Hi Laura,

Further to your email to Ellie, I just wanted to advise that our response has been drafted up and will be issued formally to you by our Planning Liaison team tomorrow.

To summarise, we have had to object to the proposal as it stands - the private package plant for disposing of foul sewage has been located on top of/ in close proximity to an existing water main that lies within the site and is covered by a legal easement.

We have advised the applicant to use our free of charge pre-development service to contact Water Developer Services as a matter of urgency in order to discuss the location of this main and their options for the relocating the package plant. Once this has taken place and a revised layout plan has been assessed by UU then we may be in a position to remove this objection.

I am on leave from tonight until the 24th, however should you need anything further please let Ellie know.

Best regards

Jenny



Jenny Quinn
Planning Manager
Planning, Landscape and Ecology
M: 07776 105657 (mobex 55657)
unitedutilities.com

If you have received a great service today why not tell us?

Visit: unitedutilities.com/wow


Coronavirus | Prevent the spread



Wash your
hands



Disinfect
common surfaces



Practise social
distancing



FEVER +
COUGH

Stay home if you
have symptoms

[Click for our message to customers](#)