

Site Details

Area: **CENRAL** WI No: **109276**
Voltage: **LV**
Circuit ID: **Memorial Hall 455760**
Span Nos: **3457 - 3458**
Surveyor: **D. HALEWOOD** Mobile No: **07827803970**

Landowner Details


Name: **MRS PENNY**
Address: **Dutton Hall**
Gallows lane
Postcode: **WA15 8JL**
Tel No: **01825 48754** Mobile No: **07825 48754**

Under the Electricity Act (1989), Electricity North West have a Duty of Care to ensure a safe and continuous supply of electricity. This includes clearing and maintaining any vegetation adjacent to any overhead powerlines or associated plant/apparatus, to a specified distance. The specified distance is set to allow for safety and the regrowth cycles of the particular tree / vegetation.

Loc No Line/Pole/ Tower Nos	Tree No	G55 / Cat	Line -L/D Work	Description of Agreed Works/Access/Arisings	Agreed clearance (metres)
⑪ 3457	T1	A5	D	Dead Ash Dismantle / Fell.	GL
3458	G1	A5	D	Mixed broadleaf side Prune / crown reduce	2-3 M
⑧ 3457 serv 49	G1	A5	L	AS ABOVE (Spruce & Beech side reduce	2.5
⑫ 3458 Aighton mill	G1	A5	D	AS side 11	

Site Plan - refer to Tree nos, access and arisings

STACK IN WOODLAND NEATLY



Landowner - please indicate any hazards that ENW staff need to be aware of (eg drains, septic tanks, etc)

Environmental / Planning Constraints - please tick the relevant boxes to identify any statutory designations you are aware of to be in place affecting the above work. Any relevant bodies will be informed / consulted.

☐ Tree Preservation Order
 ☐ Special Area of Conservation
 ☐ SSSI
 ☐ Special Protection Area
☐ RAMSAR Site
 ☐ National Nature Reserve
 ☐ Other - please specify _____

APPROVAL: I, the landowner, agree to ENW carrying out the works as described above. The work will be carried out at no cost to me.

COMPLETION DATE: To be completed by Site Supervisor

Signed: **Verbal 14.58**
Date: **1.7.20**

Team Leader: _____
Date: _____