

Ribble Valley Borough Council
Development Control
Council Offices Church Walk
Clitheroe
Lancashire
BB7 2RA

Our ref: NO/2020/113107/01-L01
Your ref: 3/2020/0940
Date: 09 December 2020

Dear Sir/Madam

**CHANGE OF USE OF LAND AND ERECTION OF BUILDING FOR HELICULTURE
(SNAIL BREEDING) TOGETHER WITH SIX LOG CABINS TO BE USED AS
HOLIDAY LETS.
LAND AT PRESTON ROAD, RIBCHESTER, PR3 3XL**

Thank you for consulting us on the above application which we received 19 November 2020

Environment Agency position

The planning application is accompanied by a Flood Risk Assessment (FRA) prepared by Flood Risk and Drainage Solutions (2020-034, 27/08/2020). We have reviewed the FRA in so far as it relates to our remit and we are satisfied that the development would be safe without exacerbating flood risk elsewhere if the proposed flood risk mitigation measures are implemented.

The proposed development must proceed in strict accordance with this FRA and the mitigation measures identified as it will form part of any subsequent planning approval. Any proposed changes to the approved FRA and / or the mitigation measures identified will require the submission of a revised FRA.

Environmental permit - advice to applicant

Boyce's Brook ordinary watercourse, forms the North East boundary of site and is designated as a Main River as it exits the site. We therefore have the following advice for the applicant:

The Environmental Permitting (England and Wales) Regulations 2016 require a permit or exemption to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culverted main river (16 metres if tidal)
- on or within 16 metres of a sea defence
- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in a floodplain more than 8 metres from the river bank, culvert or flood defence

Environment Agency
Lutra House Walton Summit, Bamber Bridge, Preston, PR5 8BX.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

structure (16 metres if it's a tidal main river) and you don't already have planning permission

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03708 506 506 (Monday to Friday, 8am to 6pm) or by emailing enquiries@environment-agency.gov.uk.

The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

Flood warning and emergency response - advice to LPA

The Planning Practice Guidance states that, if a site is classed as "more vulnerable" and used for holiday or short-let caravans, it must be subject to a specific warning and evacuation plan. As such, it is strongly recommended that this is requested from the applicant.

We do not normally comment on or approve the adequacy of flood emergency response procedures accompanying development proposals, as we do not carry out these roles during a flood. Our involvement with this development during an emergency will be limited to delivering flood warnings to occupants/users covered by our flood warning network.

The [planning practice guidance](#) (PPG) to the National Planning Policy Framework states that, in determining whether a development is safe, the ability of residents and users to safely access and exit a building during a [design flood](#) and to evacuate before an extreme flood needs to be considered. One of the key considerations to ensure that any new development is safe is whether adequate flood warnings would be available to people using the development.

In all circumstances where warning and emergency response is fundamental to managing flood risk, we advise local planning authorities to formally consider the emergency planning and rescue implications of a new development in making their decisions. As such, we recommend you consult with your emergency planners and the emergency services to determine whether the proposals are safe in accordance with the guiding principles of the PPG.

Sequential test - advice to LPA

In accordance with the National Planning Policy Framework (paragraph 158), development should not be permitted if there are reasonably available sites appropriate for the proposed development in areas with a lower probability of flooding.

It is for the local planning authority to determine if the sequential test has to be applied and whether or not there are other sites available at lower flood risk. Our flood risk standing advice reminds you of this and provides advice on how to apply the test.

Exception test - advice to LPA

In accordance with the National Planning Policy Framework, the proposed development is appropriate provided that the site meets the requirements of the exception test. Our comments on the proposals relate to the part of the exception test that demonstrates the development is safe. The local planning authority must decide whether or not the proposal provides wider sustainability benefits to the community that outweigh flood risk.

Non-mains drainage – advice to the applicant/LPA

The planning application is proposing non-mains drainage and the use of a septic tank or package treatment plant with soakaway. There is a foul sewer 55 metres from the development site boundary and approximately 100metres from the first lodge. We

would therefore take this opportunity to remind the LPA and applicant of the rules governing the disposal of foul water.

Government guidance contained within the national Planning Practice Guidance (Water supply, wastewater and water quality – considerations for planning applications, paragraph 020) sets out a hierarchy of drainage options that must be considered and discounted in the following order:

1. Connection to the public sewer
2. Package sewage treatment plant (adopted in due course by the sewerage company or owned and operated under a new appointment or variation)
3. Septic Tank

Foul drainage should be connected to the main sewer. Where this is not possible, under the Environmental Permitting Regulations 2010 any discharge of sewage or trade effluent made to either surface water or groundwater will need to be registered as an exempt discharge activity or hold a permit issued by the Environment Agency, in addition to planning permission. This applies to any discharge to inland freshwaters, coastal waters or relevant territorial waters.

Please note that the granting of planning permission does not guarantee the granting of an Environmental Permit. Upon receipt of a correctly filled in application form we will carry out an assessment. It can take up to 4 months before we are in a position to decide whether to grant a permit or not.

Domestic effluent discharged from a treatment plant/septic tank at 2 cubic metres or less to ground or 5 cubic metres or less to surface water in any 24 hour period must comply with General Binding Rules provided that no public foul sewer is available to serve the development and that the site is not within an inner Groundwater Source Protection Zone.

A soakaway used to serve a non-mains drainage system must be sited no less than 10 metres from the nearest watercourse, not less than 10 metres from any other foul soakaway and not less than 50 metres from the nearest potable water supply.

Where the proposed development involves the connection of foul drainage to an existing non-mains drainage system, the applicant should ensure that it is in a good state of repair, regularly de-sludged and of sufficient capacity to deal with any potential increase in flow and loading which may occur as a result of the development.

Where the existing non-mains drainage system is covered by a permit to discharge then an application to vary the permit will need to be made to reflect the increase in volume being discharged. It can take up to 13 weeks before we decide whether to vary a permit.

Further advice is available at:

[Septic tanks and treatment plants: permits and general binding rules](#)

Yours faithfully

Carole Woosey
Planning Advisor

E-mail clplanning@environment-agency.gov.uk