

Nicola Gunn

From: Planning
Subject: FW: 3/2021/0203

From: Brenton, Robert <
Sent: 17 June 2021 08:36
To: Adam Birkett <
Cc: Planning Liaison
Subject: RE: Consultation on planning application 3/2021/0203 Old Row, Whalley Road, Barrow BB7 9AZ
DC/21/2128

 External Email

This Email Originated Outside Ribble Valley Borough Council. Do not click links or attachments unless you recognize the sender and know the content is safe. If in doubt please contact helpdesk@ribblevalley.gov.uk

Good morning Adam,

Apologies for the delayed response. Following an assessment of the provided proposed Drainage Layout, Ref: 881590-ENG001, Rev: P10, Dated: 09.04.2021, By: RSK in support of the planning application (our ref: DC/21/2128), United Utilities concur with the LLFA's comments, the proposals appear agreeable in principle, subject to the points raised by the LLFA being addressed in addition to the following consideration: there are a number of instances where the Finished Floor Levels are below the cover level on the receiving proposed public sewer and therefore could result in the creation of a hydraulic low point, this should be addressed prior to determination. Con 7 (h).

Kind regards,



Robert Brenton
Developer Engineer
Developer Services & Metering
Customer Services
M: 07880299827
unitedutilities.com

If you have received a great service today why not tell us?

Visit: unitedutilities.com/wow

Did you know we now have a live chat facility available to you Mon to Friday 8 -5pm. You just click on the orange live chat box on our webpage and one of our advisors will be ready to chat to you and help you with your enquiry <https://www.unitedutilities.com/builders-developers/> or you can email us at developerserviceswater@uuplc.co.uk

Coronavirus


Prevent the spread



Wash your
hands



Disinfect
common surfaces



Practise social
distancing



FEVER +
COUGH

Stay home if you
have symptoms

[Click for our message to customers](#)