

## Nicola Gunn

---

**From:** Heather Barton  
**Sent:** 07 June 2021 08:58  
**To:** Planning; Adrian Dowd  
**Cc:** Environmental Health  
**Subject:** FW: Ribble Valley ref 3-2021-0269 6 the Arches Whalley COU to shop and flat

**Categories:** Yellow Category

Having Looked at the planning application for the above and the supported noise assessment . I must highlight the issues raised on Pg9 of the report regarding the noise impact from the train line for any future residents. It is with this in mind that I would suggest that the recommendation of acoustic trickle ventilators to habitable rooms.

Externally the area would benefit from a barrier attenuation , I also believe that this will have an additional impact at reducing the noise within the property .

Should you wish to discuss please contact me .

Kind Regards

Heather