

Ribble Valley Borough Council
Council Offices
Church Walk
Clitheroe
BB7 2RA

Your ref: 3/2021/0275
Our ref: DC/21/1403
Date: 11-JUN-21

Dear Sir/Madam

Location: Land behind The Dog Inn, Market Place, Longridge PR3 3RR
Proposal: Proposed erection of 9 new dwellings and associated works

With regards to the above development proposal, United Utilities Water Limited (*'United Utilities'*) wishes to provide the following updated comments following the receipt of additional information on 24 May 2021.

Drainage and Existing and Proposed Levels – REQUEST FOR ADDITIONAL INFORMATION PRIOR TO DETERMINATION

We welcome the written confirmation from the applicant regarding the proposed point of connection for foul water. We would be grateful if the applicant could indicatively identify this point of connection on a submitted plan.

With regards to the proposed ground levels, we note the submitted site sections indicate a reduction in ground levels around various plots such that the land will be significantly lower than the cover levels on the existing public sewer that passes through the site. We would therefore request that the applicant confirms the likely overland flow exceedance paths in the event that the public sewer surcharges from existing manholes. It will be important that the final topography of the site guides the flows from any surcharged manhole away from the proposed dwellings and their associated curtilages where possible. We mention this with specific reference to plot 1.

Having review the submitted cross section, the cover on top of the existing sewer that passes through the site is reduced to as little as 0.482m. This is not acceptable to United Utilities and needs further consideration with our Developer Engineer. We are also concerned that the proposed retaining wall arrangement within the rear gardens will compromise access to the

public sewer for maintenance, repair or replacement and therefore we request that the applicant contacts our Developer Engineer to discuss further. The applicant should note that we may consider a diversion of the affected public sewer as necessary at the applicant's cost given the circumstances of the proposal.

As noted previously we wish to draw to the applicant's attention to the fact that the public sewer that passes through the site is a foul only sewer. In the event that infiltration is not feasible, there is no right to connect surface water to a foul only public sewer.

Once the above matters have been fully considered, we will be able to provide further comment and recommend final detailed conditions. If, however, you are minded to favourably determine this application in advance of receiving the above information, which we do not recommend, we would recommend that you attach the following condition.

Foul and Surface Water Drainage Condition

Prior to the commencement of development, details of a sustainable surface water drainage scheme and a foul water drainage scheme shall be submitted to, and approved in writing by, the Local Planning Authority. The drainage schemes must include:

(i) An investigation of the hierarchy of drainage options in the National Planning Practice Guidance (or any subsequent amendment thereof). This investigation shall include evidence of an assessment of ground conditions and the potential for infiltration of surface water in accordance with BRE365;

(ii) A restricted rate of discharge of surface water agreed with the local planning authority (if it is agreed that infiltration is discounted by the investigations);

(iii) Levels of the proposed drainage systems including proposed ground and finished floor levels in AOD;

(iv) Incorporate mitigation measures to manage the risk of sewer surcharge;

(v) Foul and surface water shall drain on separate systems;

(vi) A management and maintenance plan. The management and maintenance plan shall include as a minimum:

a. Arrangements for adoption by an appropriate public body or statutory undertaker, or, management and maintenance by a management company; and

b. Arrangements for inspection and ongoing maintenance of all elements of the sustainable drainage system to secure the operation of the surface water drainage scheme throughout its lifetime including during construction.

(vii) A timetable for implementation.

The approved drainage schemes shall also demonstrate accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacement national standards.

The drainage schemes shall be completed, maintained and managed in accordance with the approved details and retained thereafter for the lifetime of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution.

The applicant can discuss the above matters with our Developer Engineer, **Rob Brenton**, by email at wastewaterdeveloperservices@uuplc.co.uk.

Please note, United Utilities is not responsible for advising on rates of discharge to the local watercourse system. This is a matter for discussion with the Lead Local Flood Authority and / or the Environment Agency (if the watercourse is classified as main river).

If the applicant intends to offer wastewater assets forward for adoption by United Utilities, the proposed detailed design will be subject to a technical appraisal by an Adoption Engineer as we need to be sure that the proposal meets the requirements of Sewers for Adoption and United Utilities' Asset Standards. The detailed layout should be prepared with consideration of what is necessary to secure a development to an adoptable standard. This is important as drainage design can be a key determining factor of site levels and layout. The proposed design should give consideration to long term operability and give United Utilities a cost effective proposal for the life of the assets. Therefore, should this application be approved and the applicant wishes to progress a Section 104 agreement, we strongly recommend that no construction commences until the detailed drainage design, submitted as part of the Section 104 agreement, has been assessed and accepted in writing by United Utilities. Any work carried out prior to the technical assessment being approved is done entirely at the developer's own risk and could be subject to change.

Management and Maintenance of Sustainable Drainage Systems

Without effective management and maintenance, sustainable drainage systems can fail or become ineffective. As a provider of wastewater services, we believe we have a duty to advise the Local Planning Authority of this potential risk to ensure the longevity of the surface water drainage system and the service it provides to people. We also wish to minimise the risk of a sustainable drainage system having a detrimental impact on the public sewer network should the two systems interact. We therefore recommend the Local Planning Authority include a condition in their Decision Notice regarding a management and maintenance regime for any sustainable drainage system that is included as part of the proposed development. This is reflected in our above-recommended condition. We recommend the Local Planning Authority consults with the Lead Local Flood Authority regarding the exact wording of any condition.

Please note United Utilities cannot provide comment on the management and maintenance of an asset that is owned by a third party management and maintenance company. We would not be involved in the discharge of the management and maintenance condition in these circumstances.

Water Supply

If the applicant intends to obtain a water supply from United Utilities for the proposed development, we strongly recommend they engage with us at the earliest opportunity. If

reinforcement of the water network is required to meet the demand, this could be a significant project and the design and construction period should be accounted for.

Please note, all internal pipework must comply with current Water Supply (water fittings) Regulations 1999.

To discuss a potential water supply or any of the water comments detailed above, the applicant can contact the team at DeveloperServicesWater@uuplc.co.uk.

United Utilities' Property, Assets and Infrastructure

A public sewer crosses this site and we may not permit building over it. We will require an access strip width of six metres, three metres either side of the centre line of the sewer which is in accordance with the minimum distances specified in the current issue of Part H of the Building Regulations, for maintenance or replacement. Therefore a modification of the site layout, or a diversion of the affected public sewer may be necessary. All costs associated with sewer diversions must be borne by the applicant.

To establish if a sewer diversion is feasible, the applicant must discuss this at an early stage with our Developer Engineer at wastewaterdeveloperservices@uuplc.co.uk as a lengthy lead in period may be required if a sewer diversion proves to be acceptable.

Deep rooted shrubs and trees should not be planted in the vicinity of the public sewer and overflow systems. Where United Utilities' assets exist, the level of cover to the water mains and public sewers must not be compromised either during or after construction.

For advice regarding protection of United Utilities' assets, the applicant should contact the teams as follows:

Water assets – DeveloperServicesWater@uuplc.co.uk

Wastewater assets – WastewaterDeveloperServices@uuplc.co.uk

It is the applicant's responsibility to investigate the possibility of any United Utilities' assets potentially impacted by their proposals and to demonstrate the exact relationship between any United Utilities' assets and the proposed development.

A number of providers offer a paid for mapping service including United Utilities. To find out how to purchase a sewer and water plan from United Utilities, please visit the Property Searches website at <https://www.unitedutilities.com/property-searches/>.

You can also view the plans for free. To make an appointment to view our sewer records at your local authority please contact them direct, alternatively if you wish to view the water and the sewer records at our Lingley Mere offices based in Warrington please ring [0370 751 0101](tel:03707510101) to book an appointment.

Due to the public sewer transfer in 2011, not all sewers are currently shown on the statutory sewer records and we do not always show private pipes on our plans. If a sewer is discovered during construction; please contact a Building Control Body to discuss the matter further.

Should this planning application be approved the applicant should contact United Utilities regarding a potential water supply or connection to public sewers. Additional information is available on our website <http://www.unitedutilities.com/builders-developers.aspx>

Yours faithfully

Tracy Churchman
Planning Analyst
Planning, Landscape and Ecology