

02/05/2021

Peter Hitchen Architects Mail - 14 CHU

Peter Hitchen
Architects

Peter H

14 CHURCH LANE WHALLEY

Philip Wright Ass
To: Peter Hitchen <

Hi Peter

I refer to my Structural report on the roof the above and the comments received from the Local authority. With regards to the inspection of inaccessible members, I would envisage that those hidden would be exposed following removal of the tiles and battens to enable an inspection to be undertaken. The extent of any decay can then be assessed and members repaired or replaced, dependent on the findings.

Regards

P. G. Wright



PHILIP WRIGHT
ASSOCIATES

PHILIP WRIGHT ASSOCIATES LTD

CONSULTING STRUCTURAL ENGINEERS

21 Union Street | Ramsbottom | Bury BL0 9AN

d. The recipient is responsible for virus checking this email and any
lease immediately notify us and delete this email; you must not use,

ly for any loss or damage from your receipt or use of this email.