



IN10 – Masonry in-fills, water staining



IN11 – Defelcting lintels and stone in-fill required



IN12 – Seperation of elevation walls





IN13 – Masonry in-fill – water staining at base



IN14 – Eastern section roof, some water ingress and staining noted





IN15 - Western section roof, steel UBs used to prop ridge in unorthodox fashion