Heat Pump System Performance Estimate

Installer Project Reference Manor House Client Name Brent Taylor MANOR HOUSE Installation Address Line 1 HOWGILL LANE Installation Address Line 2 LANCASHIRE Installation Address Line 3 Installation Postcode BB7 4EF





Energy Performance Certificate (EPC) Information

Does this estimate relate to a new build or proposal for extension or reduction in size of an existing building? No

Estimate based on draft EPC

Energy required to heat property 20,915 kWh Energy required for hot water 5,619 kWh

New Renewable System Information

Type of System Air Source Heat Pump

Manufacturer Name Vaillant

Manufacturer Model Arotherm plus 12kW

KIWA 00016/020 HP MCS Certification Number

50 °C Flow Temperature

MCS SCOP Heating 3.92

MCS SCOP Hot Water 1.75

Renewable System Provides

Heating and Hot Water

Hot Water Immersion Use Once per week

Size of Hot Water Cylinder 250 ltr * This calculator is not designed to be used for Solar Assisted Heat Pumps

* Available from the MCS Product Directory

* Determined by the temp. of the water leaving the HP when supplying space heating at the external design temp.

st SCoP - Seasonal Coefficient of Performance. This value is based on the MCS HP SCoP Table below

 * If providing space heating and DHW, default value from SAP2012. IF DHW only see methodology in MIS3005

 * based on 50°C up to 60°C, 3kW

Existing Heating System

Existing heating system fuel Oil * If new build model the most likely alternative fuel. Oil * If new build model the most likely alternative fuel. Hot Water heated by

Post-2007 Age of existing system Efficiency of existing system 92 %

Estimated System Performance / Comparsion

Energy Requirement for the building

	Heating	Hot water	Total	
Net Energy required to heat property	20,915	5,619	26,534	kWh
Existing System Consumption	22,734	6,786	29,520	kWh

New HP System Estimated Consumption

Full Heat Pump System (if selected above)


HP System Electricity Consumption 5.335 3.362 8.697 kWh

Hybrid System (if selected above)

0 0 **HP System Electricity Consumption** 0 kWh Hybrid system other Consumption 0 0 0 kWh **Hybrid Total Consumption** Ω kWh

Note: There are different types of hybrid system. This calculation presumes a hybrid where both sources of heat supply the same hydraulic circuits (heating and hot water) according to the proportion selected above.

Electricity Consumption of Proposed Heat Pump for Space Heating versus Flow Temperature



Flow temperature SCOP 35°C 4.88 36°C 4.81 37°C 4.75 38°C 4.68 39°C 4.61 4.0°C 4.55 41°C 4.48 42°C 4.41 43°C 4.35 44°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 50°C 3.92 51°C 3.86 52°C 3.86 52°C 3.86 52°C 3.63 56°C 0 55°C 0 0 55°C 0 0 60°C 0 0 61°C 0 0 62°C 0 66°C 0		
36°C 4.81 37°C 4.75 38°C 4.68 39°C 4.61 40°C 4.55 41°C 4.48 42°C 4.41 43°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 0 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	Flow temperature	SCOP
37°C 4.75 38°C 4.68 39°C 4.61 40°C 4.55 41°C 4.48 42°C 4.41 43°C 4.28 45°C 4.21 46°C 4.15 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	35℃	4.88
38°C 4.68 39°C 4.61 40°C 4.55 41°C 4.48 42°C 4.41 43°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 60°C 0 60°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	36°C	-
39°C 4.61 40°C 4.55 41°C 4.48 42°C 4.41 43°C 4.35 44°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 0 55°C 0 55°C 0 55°C 0 56°C 0 57°C 0 58°C 0 60°C 0 60°C 0 60°C 0 62°C 0 63°C 0	37℃	4.75
40°C 4.55 41°C 4.48 42°C 4.41 43°C 4.35 44°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	38℃	4.68
41°C 4.48 42°C 4.41 43°C 4.35 44°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 3.98 50°C 3.92 51°C 3.86 52°C 3.87 53°C 3.74 54°C 0 55°C 0 55°C 0 55°C 0 55°C 0 56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 60°C 0 60°C 0 60°C 0 60°C 0	39℃	4.61
42°C 4.41 43°C 4.35 44°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	40°C	4.55
43°C 4.35 44°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	41°C	4.48
44°C 4.28 45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 0 55°C 0 60°C 0 61°C 0 62°C 0 64°C 0 66°C 0 66°C 0 66°C 0	42°C	4.41
45°C 4.21 46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 0 57°C 0 58°C 0 60°C 0 61°C 0 62°C 0 64°C 0 64°C 0 61°C 0 66°C 0	43°C	4.35
46°C 4.15 47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	44°C	4.28
47°C 4.1 48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	45°C	4.21
48°C 4.04 49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	46°C	4.15
49°C 3.98 50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	47°C	4.1
50°C 3.92 51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 60°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	48°C	4.04
51°C 3.86 52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	49°C	3.98
52°C 3.8 53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	50°C	3.92
53°C 3.74 54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	51°C	3.86
54°C 3.69 55°C 3.63 56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	52℃	3.8
55°C 3.63 56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	53℃	3.74
56°C 0 57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	54°C	3.69
57°C 0 58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	55°C	3.63
58°C 0 59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	56℃	0
59°C 0 60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	57℃	0
60°C 0 61°C 0 62°C 0 63°C 0 64°C 0	58℃	0
61°C 0 62°C 0 63°C 0 64°C 0	59℃	0
62°C 0 63°C 0 64°C 0	60°C	0
63°C 0 64°C 0	61°C	0
64°C 0	62°C	0
* * * * * * * * * * * * * * * * * * * *	63°C	0
65°C 0	64°C	0
	65°C	0

SCoP Definition

SCoP = Seasonal Coefficient of Performance:

MCS SCoP is a theoretical indication of the anticipated efficiency of a heat pump aggregated over a year using standard climate data across Europe. It indicates the units of total heat energy generated (output) for each unit of energy (electricity) consumed (input). It is slightly different to ErP SCoP as it contains efficency losses due to controls and brine pumps (for a GSHP). As a guide a heat pump with a MCS SCoP of 3 generates 3 kWh of heat energy for every 1 kWh of electrical energy it consumes.

This also means that 2/3rds of the heat output could be eligible for RHI payments. MCS SCOP is based on stringent factory based tests for equipment but does not specifically include the energy consumption of heating circulating pump(s) nor does it model the transient conditions typically experienced in practice in the consumers home and hence the overall final system efficiency is likely to be different from the MCS SCOP.

Important Information

This performance estimate should be accompanied by the Key Facts which explain the factors that can affect the performance of a heat pump.

Any technical variation to the specification could affect the performance of the Heat Pump System in which case the MCS Contractor MUST update and re-issue this document and advise the customer of their Consumer Rights.