

United Utilities Water Limited

Grasmere House Lingley Mere Business Park Lingley Green Avenue Great Sankey Warrington WA5 3LP

unitedutilities.com

Planning.Liaison@uuplc.co.uk

Ribble Valley Borough Council By email

Our ref: DC/22/3994
Date: 07-DEC-22

Your ref: 3/2022/1039

Dear Planning Team

Location: Land adjacent to 115 Kemple View Clitheroe BB7 2QJ

Proposal: Proposed construction of two new detached dwellings with associated access and

garden areas

United Utilities wish to make the following comments regarding the proposal detailed above.

DRAINAGE

Following our review of the submitted drainage documents; Drainage Strategy Ref: PHA/366 100, Dated 12.10.2022, the plans are not acceptable to United Utilities. This is because there is insufficient information on the detail of the drainage design and we have not seen robust evidence that that the drainage hierarchy has been thoroughly investigated and the proposals are not in line with the Non-Statutory Technical Standards for Sustainable Drainage Systems

Should planning permission be granted we request the following condition is attached to any subsequent Decision Notice:

CONDITION

Prior to the commencement of development, details of a sustainable surface water drainage scheme and a foul water drainage scheme shall be submitted to and approved in writing by the Local Planning Authority. The drainage schemes must include:

- (i) An investigation of the hierarchy of drainage options in the National Planning Practice Guidance (or any subsequent amendment thereof). This investigation shall include evidence of an assessment of ground conditions and the potential for infiltration of surface water in accordance with BRE365;
- (ii) A restricted rate of discharge of surface water agreed with the local planning authority (if it is agreed that infiltration is discounted by the investigations);

- (iii) Levels of the proposed drainage systems including proposed ground and finished floor levels in AOD;
- (iv) Incorporate mitigation measures to manage the risk of sewer surcharge where applicable; and
- (v) Foul and surface water shall drain on separate systems.

The approved schemes shall also be in accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacement national standards.

Prior to occupation of the proposed development, the drainage schemes shall be completed in accordance with the approved details and retained thereafter for the lifetime of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution.

REQUEST FOR ADDITIONAL INFORMATION

We request that the applicant submits a plan outlining the proposed levels (including finished floor levels and ground levels) shown in metres above Ordnance Datum and an indicative foul and surface water drainage strategy (including cover and invert levels). It is our recommendation this information is submitted for our review so that any risk of sewer surcharge can be further assessed. The applicant should note that it may be necessary to raise finished floor and ground levels and / or include mitigation measures to manage the risk of sewer surcharge.

The applicant can discuss any of the above with Developer Engineer, **Gary Jaundrell**, by email at wastewaterdeveloperservices@uuplc.co.uk.

Please note, United Utilities is not responsible for advising on rates of discharge to the local watercourse system. This is a matter for discussion with the Lead Local Flood Authority and / or the Environment Agency (if the watercourse is classified as main river).

If the applicant intends to offer wastewater assets forward for adoption by United Utilities, their proposed detailed design will be subject to a technical appraisal by our Developer Services team and must meet the requirements outlined in 'Sewerage Sector Guidance Appendix C – Design and Construction Guidance v2-2' dated 29 June 2022 or any subsequent iteration. This is important as drainage design can be a key determining factor of site levels and layout.

Acceptance of a drainage strategy does not infer that a detailed drainage design will meet the requirements for a successful adoption application. We strongly recommend that no construction commences until the detailed drainage design, has been assessed and accepted in writing by United Utilities. Any work carried out prior to the technical assessment being approved is done entirely at the developer's own risk and could be subject to change.

Management and Maintenance of Sustainable Drainage Systems

Without effective management and maintenance, sustainable drainage systems can fail or become ineffective. As a provider of wastewater services, we believe we have a duty to advise the Local Planning Authority of this potential risk to ensure the longevity of the surface water drainage system and the service it provides to people. We also wish to minimise the risk of a sustainable drainage system having a detrimental impact on the public sewer network should the two systems interact. We therefore recommend the Local Planning Authority include a condition in their Decision Notice regarding a management and maintenance regime for any sustainable drainage system that is included as part of the proposed development. You may find the condition below a useful example.

Prior to occupation of the development a sustainable drainage management and maintenance plan for the lifetime of the development shall be submitted to the local planning authority and agreed in writing. The sustainable drainage management and maintenance plan shall include as a minimum:

- a. Arrangements for adoption by an appropriate public body or statutory undertaker, or, management and maintenance by a resident's management company; and
- b. Arrangements for inspection and ongoing maintenance of all elements of the sustainable drainage system to secure the operation of the surface water drainage scheme throughout its lifetime.

The development shall subsequently be completed, maintained and managed in accordance with the approved plan.

Reason: To ensure that management arrangements are in place for the sustainable drainage system in order to manage the risk of flooding and pollution during the lifetime of the development.

Please note United Utilities cannot provide comment on the management and maintenance of an asset that is owned by a third party management and maintenance company. We would not be involved in the discharge of the management and maintenance condition in these circumstances.

WATER AND WASTEWATER SERVICES

If the applicant intends to receive water and/or wastewater services from United Utilities, they should visit our website or contact the Developer Services team for advice. This includes seeking confirmation of the required metering arrangements for the proposed development.

If the proposed development site benefits from existing water and wastewater connections, the applicant should not assume that the arrangements will be suitable for the new proposal.

In some circumstances we may require a compulsory meter is fitted. For detailed guidance on whether the development will require a compulsory meter please visit https://www.unitedutilities.com/my-account/your-bill/our-household-charges-20212022/ and go to section 7.7 for compulsory metering.

If reinforcement of the water network is required to meet potential demand, this could be a significant project and the design and construction period should be accounted for.

To avoid any unnecessary costs and delays being incurred by the applicant or any subsequent developer, we strongly recommend the applicant seeks advice regarding water and wastewater services, and metering arrangements, at the earliest opportunity. Please see 'Contacts' section below.

UNITED UTILITIES PROPERTY, ASSETS AND INFRASTRUCTURE

Water pipelines

<u>United Utilities will not allow building over or in close proximity to a water main.</u>

Wastewater pipelines

<u>United Utilities will not allow a new building to be erected over or in close proximity to a public sewer or any other wastewater pipeline</u>. This will only be reviewed in <u>exceptional</u> circumstances. *Nb. Proposals to extend domestic properties either above, or in close proximity to a public sewer will be reviewed on a case by case basis by either by a building control professional or following a direct application to United Utilities (see our website for further details).*

REQUEST FOR INFORMATION PRIOR TO DETERMINATION

Following our review of the proposed site layout, we have concerns regarding the proximity of proposed development to our wastewater asset(s). To resolve this matter, and to avoid any unnecessary costs or delays to either the applicant or any future developer, we request the applicant submits a detailed site layout plan which overlays the proven location (exact line and depth) of the sewer in relation to any proposed development (including walls, fencing, parking etc.). Without this information we are unable to provide further comment and there is a risk that as the scheme progresses, the applicant, or any subsequent developer, may discover that their plans are not implementable in their existing form.

Furthermore, we request a 10m easement from the 1100 brick egg sewer in line with our easement local practice, due to the criticality of the sewer. (https://www.unitedutilities.com/globalassets/documents/builders--developers-docs/easement-local-practice.pdf)

Therefore, we strongly recommend this matter is resolved PRIOR TO DETERMINATION. The applicant should contact our Developer Services team to discuss. See Contacts Section below.

Advice relating to both water and wastewater infrastructure

It is the applicant's responsibility to demonstrate the exact relationship between United Utilities' assets and the proposed development. Developer's should investigate the existence and the precise location of water and wastewater pipelines as soon as possible as this could significantly

impact the preferred site layout and/or diversion of the asset(s) may be required. Where United Utilities' assets cross the proposed red line boundary, developers must contact our Developer Services team prior to commencing any works on site, including trial holes, groundworks or demolition.

Unless there is specific provision within the title of the property or an associated easement, any necessary disconnection or diversion of assets to accommodate development, will be at the applicant/developer's expense. In some circumstances, usually related to the size and nature of the assets impacted by proposals, developers may discover the cost of diversion is prohibitive in the context of their development scheme.

Any agreement to divert our underground assets will be subject to a diversion application, made directly to United Utilities. This is a separate matter to the determination of a planning application. We will not guarantee, or infer acceptance of a proposed diversion through the planning process (where diversion is indicated on submitted plans). In the event that a diversion application is submitted to United Utilities and subsequently rejected (either before or after the determination of a planning application), applicants should be aware that they may need to amend their proposed layout to accommodate United Utilities' assets.

Where United Utilities' assets exist, the level of cover to United Utilities pipelines and apparatus must not be compromised either during or after construction and there should be no additional load bearing capacity on pipelines without prior agreement from United Utilities. This would include earth movement and the transport and position of construction equipment and vehicles.

Any construction activities in the vicinity of United Utilities' assets, including any assets or infrastructure that may be located outside the applicant's red line boundary, must comply with national building and construction standards and where applicable, our 'Standard Conditions for Works Adjacent to Pipelines'. The applicant, and/or any subsequent developer should note that our 'Standard Conditions' guidance applies to any design and construction activities in close proximity to water pipelines and apparatus that are no longer in service, as well as pipelines and apparatus that are currently operational. A copy of this document is available on our website.

The applicant or developer should contact our Developer Services team for advice if their proposal is in the vicinity of water or wastewater pipelines and apparatus. It is their responsibility to ensure that United Utilities' required access is provided within their layout and that our infrastructure is appropriately protected. The developer would be liable for the cost of any damage to United Utilities' assets resulting from their activity. Please see 'Contacts' section below.

CONTACTS

Website

For detailed guidance on water and wastewater services, including application forms and the opportunity to talk to the Developer Services team using the **'Live Chat'** function, please visit:

http://www.unitedutilities.com/builders-developers.aspx

Email

For advice on water and wastewater services or to discuss proposals near to pipelines, email the Developer Services team as follows:

Water mains and water supply, including metering - <u>DeveloperServicesWater@uuplc.co.uk</u>

Public sewers and drainage - <u>WastewaterDeveloperServices@uuplc.co.uk</u>

Telephone - 0345 072 6067

Property Searches (for asset maps):

A number of providers offer a paid for mapping service including United Utilities. For more information, or to purchase a sewer and water plan from United Utilities, please visit https://www.unitedutilities.com/property-searches/

Water and sewer records can be viewed for free at our Warrington Head Office by calling 0370 751 0101. Appointments must be made in advance. Public sewer records can be viewed at local authority offices. Arrangements should be made directly with the local authority.

The position of the underground apparatus shown on asset maps is approximate only and is given in accordance with the best information currently available. United Utilities Water will not accept liability for any loss or damage caused by the actual position being different from those shown on the map.

We request that a copy of this letter is made available to the applicant.

Yours faithfully

The Planning, Landscape and Ecology Team