

31202310282
2014/2023

Joiners Report for Replacement Windows and Stable Door

7 Talbot Street, Chipping

Dear Sirs,

Windows were manufactured out of Sapele hardwood timber, they were rebated, profiled and then glued and screwed together to form the window frame.

They were screwed into the brickwork, then foamed around any gaps, then finished with a white sealant.

Softcoat 24mm double glazed units were installed to frames, on a dry glazing tape and sealant around the glass to sure no water penetrates.

Stable door and frame were manufactured out of Accoya timber.

Fitted with single glazed glass.

Multipoint locking strip and furniture fitted to door and frame.