



EXTERNAL WORKS

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTS' ENGINEERS' AND SPECIALISTS' DRAWINGS, TOGETHER WITH THE APPROPRIATE SPECIFICATION.

IT IS THE CONTRACTOR'S RESPONSIBILITY TO CHECK ALL DIMENSIONS ON SITE. DIMENSIONS MUST NOT BE SCALED FROM THIS DRAWING. ANY DISCREPANCIES TO BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE ARCHITECT IN WRITING.

ALL DIMENSIONS ARE IN MILLIMETRES, UNLESS NOTED OTHERWISE. ALL LEVELS ARE IN METRES, UNLESS NOTED OTHERWISE.

ALL KERBS TO BE INSTALLED WITH 125mm FACE TO ACCESS ROADS AND 100mm IN CAR PARK AREA UNLESS NOTED OTHERWISE.

THE FINISHED LEVEL IN PAVEMENT AREAS SHALL BE WITHIN PLUS OR MINUS 5mm OF THE DESIGN PROFILE.

LEGEND

- PROPOSED KERB LINE
- PROPOSED FINISHED FLOOR LEVEL
- PROPOSED LEVEL
- EXISTING LEVEL (FROM SURVEY)
- TRAPPED ROAD GULLY
- LINEAR DRAINAGE CHANNEL

PAVEMENT NOTES

NOTE: LIME STONE COARSE AGGREGATE SHALL NOT BE USED FOR ASPHALT SURFACE COURSES. BOND COAT IS TO BE APPLIED IN ACCORDANCE WITH BS 594:97 BETWEEN ALL CARBON PAVING MATERIAL LAYERS. REDUCED FORMATION LEVEL TO BE PROOF ROLLED TO IDENTIFY SOFT SPOTS. SOFT SPOTS TO BE EXCAVATED AND BACKFILLED WITH 6F5 CARBON PAVING MATERIAL.


ALL ASPHALT MIXTURES TO CONFORM TO BS EN 13108

ALL BLOCK PAVING REFERENCES TO CONFORM TO BS 7533

SUBJECT TO CBR TESTING

- ACCESS ROAD
 - 30mm SMA TO SURF AND 80mm AC 32 DENSE BASE 100/150
 - 250mm SUB-BASE DOT TYPE 1
- CAR PARKING BAYS
 - 30mm SMA TO SURF AND 60mm AC 30 DENSE BHN 100/150
 - 200mm SUB-BASE DOT TYPE 1
- TARMAK FOOTWAY CONSTRUCTION
 - 20mm AC 30 DENSE BHN 100/150
 - 150mm SUB-BASE DOT TYPE 1
- CONCRETE BIN STORE
 - 100mm C28/35 CONCRETE SLAB WITH BRUSHED FINISH & ARMED EDGE WITH 1 LAYER OF A442 HESH TO BS4483
 - 150mm SUB-BASE DOT TYPE 1
- ASPH BASE / SPRINKLER TANK BASE
 - PAVEMENT COMPOSITION AND LEVEL REQUIREMENTS TO BE DETERMINED BY ARCHITECT
- BLOCK PAVING - FOOTWAY
 - 50mm BLOCK PAVIOR TO ARCHITECTS SPEC
 - 40mm CAT IV SAND LAYING COURSE (BS 7533)
 - 150mm SUB-BASE DOT TYPE 1

PROPOSED SPINE ROAD



REV	DESCRIPTION	BY	CHK	APP	DATE
R04	CAR PARK LAYOUT AMENDED	JR	RH	MM	21.11.2023
R03	ISSUED FOR TENDER	JR	RH	MM	16.05.2023
R02	SITE LAYOUT AMENDED	JR	RH	MM	28.03.2023

PROJECT	CUTHEROE CARE HOME
TITLE	EXTERNAL WORKS PAVEMENT COMPOSITION
CLIENT	ERIC WRIGHT CONSTRUCTION LTD

DRAWN BY	JR	CHECKED BY	RH	APPROVED BY	MM
DATE	15.02.2023	SCALE (@ A1)	1:250	PROJECT NUMBER	113001

DRAWING NUMBER 220018JPS-ZZ-ZZ-DR-C-00702 REV P04